

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF FEB -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	04/02/2025 08:39	04/02/2025 18:05	09:26	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	99.106%
400 KV Darbhanga - Muzaffarpur circuit - 2	05/02/2025 09:24	05/02/2025 17:53	08:29	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
400/220KV 500MVA ICT No.1	06/02/2025 10:35	06/02/2025 20:07	09:32	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
400/220KV 500MVA ICT No.2	07/02/2025 10:25	07/02/2025 15:56	05:31	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
Darbhanga 125 MVar Bus reactor-1	21/02/2025 09:33	21/02/2025 15:18	05:45	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
Darbhanga 125 MVar Bus reactor-2	22/02/2025 10:03	22/02/2025 14:16	04:13	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
400 kV Motihari - Barh Circuit - 1	2/1/2025 9:38	2/1/2025 13:33		03:55	NIL	NIL	Emergency Shutdown taken by RTAMC.	
400 kV Motihari - Barh Circuit - 1	2/11/2025 9:33	2/11/2025 11:46	02:13	NIL	NIL	NIL	Emergency Shutdown taken by DMTCL for Bushing Jumper rectification.	
400 kV Motihari - Barh Circuit - 1	2/24/2025 9:59	2/24/2025 18:51	08:52	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
400 kV Motihari - Barh Circuit - 2	2/26/2025 8:40	2/26/2025 19:09	10:29	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400 KV Motihari - Gorakhpur Circuit - 2	2/15/2025 18:04	2/15/2025 22:26	NIL	04:22	NIL	NIL	Emergency Shutdown taken by PGCIL Gorakhpur.
400KV 80MVAR Line Reactor No.1	2/1/2025 9:38	2/1/2025 13:33	NIL	03:55	NIL	NIL	Emergency Shutdown taken by RTAMC.
400KV 80MVAR Line Reactor No.1	2/11/2025 9:33	2/11/2025 11:46	02:13	NIL	NIL	NIL	LR Shutdown with Line.
400KV 80MVAR Line Reactor No.1	2/24/2025 9:59	2/24/2025 18:51	08:52	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.
400KV 80MVAR Line Reactor No.2	2/26/2025 8:40	2/26/2025 19:09	10:29	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	2/25/2025 11:28	2/25/2025 14:57	03:29	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.
Motihari 125MVAR Bus Reactor No.2	2/25/2025 8:34	2/25/2025 11:22	02:48	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL