

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JULY -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissio n Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.809%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	7/8/2024 21:06	7/12/2024 6:05	NIL	NIL	NIL	80:59	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	7/15/2024 22:46	7/17/2024 16:19	NIL	NIL	NIL	41:33	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	7/17/2024 23:22	7/19/2024 7:20	NIL	NIL	NIL	31:58	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	7/19/2024 21:23	7/28/2024 7:49	NIL	NIL	NIL	202:26	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	7/28/2024 21:21	7/31/2024 17:06	NIL	NIL	NIL	67:45	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	7/1/2024 0:00	7/2/2024 7:54	NIL	NIL	NIL	31:54	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	7/9/2024 22:53	7/12/2024 7:44	NIL	NIL	NIL	56:51	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	7/18/2024 0:09	7/25/2024 8:09	NIL	NIL	NIL	176:00	For Bus voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	7/28/2024 22:18	7/31/2024 17:49	NIL	NIL	NIL	67:31	For Bus voltage regulation.	
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400 kV Motihari - Barh Circuit - 2	7/30/2024 17:44	7/30/2024 17:55	NIL	00:11	NIL	NIL	DT received from NTPC Barh, At the time of tripping line is in charged condition at NTPC Barh end.
400 kV Motihari - Gorakhpur Circuit - 1	7/15/2024 4:30	7/15/2024 15:55	11:25	NIL	NIL	NIL	Line Tripped in Zone-1, B-Phase fault, FC-9.5KA, F.D - 8.2KM
400 KV Motihari - Gorakhpur Circuit - 2	7/9/2024 5:40	7/9/2024 18:33	12:53	NIL	NIL	NIL	Line Tripped in Zone-1, R-Phase fault, FC- 10.22KA, Zone -1, F.D - 7.8KM
400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	7/30/2024 17:44	7/30/2024 17:55	NIL	00:11	NIL	NIL	DT received from NTPC Barh, At the time of tripping line is in charged condition at NTPC Barh end.
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	7/1/2024 0:00	7/1/2024 15:36	NIL	NIL	NIL	15:36	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/1/2024 21:09	7/2/2024 7:46	NIL	NIL	NIL	10:37	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/8/2024 19:22	7/11/2024 7:59	NIL	NIL	NIL	60:37	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/13/2024 19:51	7/14/2024 7:50	NIL	NIL	NIL	11:59	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/17/2024 21:48	7/19/2024 7:17	NIL	NIL	NIL	33:29	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/19/2024 21:24	7/20/2024 7:46	NIL	NIL	NIL	10:22	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/20/2024 21:58	7/21/2024 9:19	NIL	NIL	NIL	11:21	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	7/21/2024 22:45	7/29/2024 5:34	NIL	NIL	NIL	174:49	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	7/1/2024 0:00	7/2/2024 5:58	NIL	NIL	NIL	29:58	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	7/8/2024 21:25	7/12/2024 7:42	NIL	NIL	NIL	82:17	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	7/13/2024 22:20	7/17/2024 15:07	NIL	NIL	NIL	88:47	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	7/17/2024 21:54	7/19/2024 7:22	NIL	NIL	NIL	33:28	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	7/20/2024 21:54	7/22/2024 5:20	NIL	NIL	NIL	31:26	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	7/28/2024 19:43	7/31/2024 7:03	NIL	NIL	NIL	59:20	For Bus voltage regulation.

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL