

Darbhangha-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAR -2025

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.042%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhangha 125 MVAR Bus reactor-1	NIL TRIPPING							
Darbhangha 125 MVAR Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	3/22/2025 9:36	3/22/2025 17:03	NIL	07:27	NIL	NIL	Emergency Shutdown taken by RTAMC.	
400 kV Motihari - Barh Circuit - 2	3/23/2025 9:49	3/23/2025 17:47	NIL	07:58	NIL	NIL	Emergency Shutdown taken by RTAMC.	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	3/22/2025 9:36	3/22/2025 17:03	NIL	07:27	NIL	NIL	Emergency Shutdown taken by RTAMC.	
400KV 80MVAR Line Reactor No.2	3/23/2025 9:49	3/23/2025 17:47	NIL	07:58	NIL	NIL	Emergency Shutdown taken by RTAMC.	
400/132KV 200MVA ICT No.1	3/1/2025 9:12	3/9/2025 14:37	197:25	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
400/132KV 200MVA ICT No.2	3/9/2025 16:20	3/9/2025 18:29	02:09	NIL	NIL	NIL	Shutdown taken by DMTCL for AMP work.	
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING							
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING							

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL