

Darbhangha-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.976%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhangha 125 MVar Bus reactor-1	5/1/2024 0:00	5/8/2024 0:42	NIL	NIL	NIL	168:42	For Bus voltage regulation.	
Darbhangha 125 MVar Bus reactor-1	5/16/2024 21:18	5/20/2024 8:47	NIL	NIL	NIL	83:29	For Bus voltage regulation.	
Darbhangha 125 MVar Bus reactor-1	5/24/2024 21:31	5/30/2024 21:45	NIL	NIL	NIL	144:14	For Bus voltage regulation.	
Darbhangha 125 MVar Bus reactor-2	5/1/2024 0:00	5/4/2024 5:43	NIL	NIL	NIL	77:43	For Bus voltage regulation.	
Darbhangha 125 MVar Bus reactor-2	5/17/2024 20:40	5/20/2024 9:02	NIL	NIL	NIL	60:22	For Bus voltage regulation.	
Darbhangha 125 MVar Bus reactor-2	5/30/2024 12:51	5/30/2024 21:47	NIL	NIL	NIL	08:56	For Bus voltage regulation.	
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400 KV Motihari - Gorakhpur Circuit - 2	5/23/2024 10:28	5/23/2024 11:11	NIL	00:43	NIL	NIL	Attached Mail-1 Emergency shutdown of 400KV Motihari - Gorakhpur Circuit 2 Operation Details- Emergency Shutdown taken by DMTCL due to conductor repairing work. Note: DMTCL informed ERLDC- The PGCIL/Gorakhpur delay opening/Closing activity of isolation.
400 KV Motihari - Gorakhpur Circuit - 2	5/23/2024 11:11	5/23/2024 14:15	03:04	NIL	NIL	NIL	Emergency Shutdown taken by DMTCL due to conductor repairing work. Note: DMTCL informed to ERLDC- The PGCIL/Gorakhpur delay opening/Closing activity of isolation. Hence, outage has been considered at DMTCL part 11:11 Hrs. to 14:15 Hrs. Future/Post 11:11 Hrs./14.15 Hrs. outage is at CPCC part for their ISO/ES testing activity. (Communication mail attached)
400 KV Motihari - Gorakhpur Circuit - 2	5/23/2024 14:15	5/23/2024 15:24	NIL	01:09	NIL	NIL	Attached Mail-2 Restoration of 400KV Motihari - Gorakhpur Circuit 2 Operation Details-Emergency Shutdown taken by DMTCL due to conductor repairing work. Note: DMTCL informed ERLDC- The PGCIL/Gorakhpur delay opening/Closing activity of isolation.
400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	NIL TRIPPING						

Darbhangha-Motihari Transmission Company Limited

400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	5/1/2024 0:00	5/2/2024 13:13	NIL	NIL	NIL	37:13	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	5/14/2024 21:02	5/20/2024 7:52	NIL	NIL	NIL	130:50	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	5/24/2024 19:32	5/27/2024 7:59	NIL	NIL	NIL	60:27	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	5/21/2024 19:29	5/27/2024 7:28	NIL	NIL	NIL	131:59	For Bus voltage regulation.

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL