

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissio n Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	11/24/2024 8:02	11/24/2024 18:29	NIL	10:27	NIL	NIL	Shutdown taken by RTAMC for Insulator replacement.	
400 kV Motihari - Barh Circuit - 2	11/3/2024 16:12	11/3/2024 17:06	NIL	00:54	NIL	NIL	DTT received from NTPC Barh. Fault Phase- B, Fault current- 6.531kA, Fault Distance-58.49km	
400 kV Motihari - Barh Circuit - 2	11/4/2024 6:56	11/4/2024 10:48	NIL	03:52	NIL	NIL	Emergency shutdown taken by RTAMC.	
400 kV Motihari - Barh Circuit - 2	11/11/2024 8:31	11/11/2024 18:17	NIL	09:46	NIL	NIL	Shutdown taken by NTPC Barh.	
400 kV Motihari - Barh Circuit - 2	11/25/2024 8:15	11/25/2024 18:27	NIL	10:12	NIL	NIL	Shutdown taken by RTAMC for Insulator replacement.	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							

Darbhangha-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	11/24/2024 8:02	11/24/2024 18:29	NIL	10:27	NIL	NIL	Shutdown taken by RTAMC for Insulator replacement.
400KV 80MVAR Line Reactor No.2	11/3/2024 16:12	11/3/2024 17:06	NIL	00:54	NIL	NIL	DTT received from NTPC Barh. Fault Phase- B, Fault current- 6.531kA, Fault Distance-58.49km
400KV 80MVAR Line Reactor No.2	11/4/2024 6:56	11/4/2024 10:48	NIL	03:52	NIL	NIL	Emergency shutdown taken by RTAMC.
400KV 80MVAR Line Reactor No.2	11/11/2024 8:31	11/11/2024 18:17	NIL	09:46	NIL	NIL	Shutdown taken by NTPC Barh.
400KV 80MVAR Line Reactor No.2	11/25/2024 8:15	11/25/2024 18:27	NIL	10:12	NIL	NIL	Shutdown taken by RTAMC for Insulator replacement.
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL