

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF SEP -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVAR Bus reactor-1	9/2/2024 21:31	9/5/2024 6:31	NIL	NIL	NIL	57:00	For Bus voltage regulation.	
Darbhanga 125 MVAR Bus reactor-1	9/5/2024 21:14	9/6/2024 4:10	NIL	NIL	NIL	06:56	For Bus voltage regulation.	
Darbhanga 125 MVAR Bus reactor-1	9/6/2024 19:24	9/8/2024 15:11	NIL	NIL	NIL	43:47	For Bus voltage regulation.	
Darbhanga 125 MVAR Bus reactor-1	9/8/2024 19:24	9/13/2024 6:51	NIL	NIL	NIL	107:27	For Bus voltage regulation.	
Darbhanga 125 MVAR Bus reactor-1	9/18/2024 02:48	9/22/2024 5:59	NIL	NIL	NIL	79:11	For Bus voltage regulation.	
Darbhanga 125 MVAR Bus reactor-1	9/22/2024 20:25	9/26/2024 9:12	NIL	NIL	NIL	84:47	For Bus voltage regulation.	
Darbhanga 125 MVAR Bus reactor-2	9/1/2024 0:00	9/1/2024 8:53	NIL	NIL	NIL	08:53	For Bus voltage regulation.	100%
Darbhanga 125 MVAR Bus reactor-2	9/2/2024 21:03	9/4/2024 7:29	NIL	NIL	NIL	34:26	For Bus voltage regulation.	

Darbhanga-Motihari Transmission Company Limited

Darbhanga 125 MVAR Bus reactor-2	9/7/2024 20:29	9/11/2024 9:15	NIL	NIL	NIL	84:46	For Bus voltage regulation.
Darbhanga 125 MVAR Bus reactor-2	9/12/2024 20:47	9/14/2024 5:47	NIL	NIL	NIL	33:00	For Bus voltage regulation.
Darbhanga 125 MVAR Bus reactor-2	9/20/2024 21:22	9/25/2024 9:17	NIL	NIL	NIL	107:55	For Bus voltage regulation.
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING						
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING						
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	NIL TRIPPING						
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	9/1/2024 0:00	9/1/2024 7:37	NIL	NIL	NIL	07:37	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/1/2024 22:19	9/3/2024 6:33	NIL	NIL	NIL	32:14	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/4/2024 21:23	9/5/2024 6:33	NIL	NIL	NIL	09:10	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/5/2024 21:11	9/6/2024 4:10	NIL	NIL	NIL	06:59	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/6/2024 19:18	9/8/2024 14:40	NIL	NIL	NIL	43:22	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/8/2024 19:19	9/10/2024 7:56	NIL	NIL	NIL	36:37	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/18/2024 20:44	9/21/2024 5:57	NIL	NIL	NIL	57:13	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/21/2024 20:56	9/24/2024 7:03	NIL	NIL	NIL	58:07	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.1	9/24/2024 21:03	9/25/2024 9:15	NIL	NIL	NIL	12:12	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/1/2024 0:00	9/1/2024 7:40	NIL	NIL	NIL	07:40	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/2/2024 22:35	9/4/2024 7:27	NIL	NIL	NIL	32:52	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/5/2024 19:16	9/6/2024 4:04	NIL	NIL	NIL	08:48	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/6/2024 20:40	9/8/2024 15:13	NIL	NIL	NIL	42:33	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/8/2024 19:24	9/10/2024 7:59	NIL	NIL	NIL	36:35	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/10/2024 19:10	9/11/2024 8:54	NIL	NIL	NIL	13:44	For Bus voltage regulation.

Darbhanga-Motihari Transmission Company Limited

Motihari 125MVAR Bus Reactor No.2	9/13/2024 19:13	9/14/2024 5:52	NIL	NIL	NIL	10:39	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/16/2024 18:57	9/17/2024 15:48	NIL	NIL	NIL	20:51	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/19/2024 19:27	9/22/2024 5:49	NIL	NIL	NIL	58:22	For Bus voltage regulation.
Motihari 125MVAR Bus Reactor No.2	9/22/2024 19:26	9/25/2024 7:29	NIL	NIL	NIL	60:03	For Bus voltage regulation.

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL