

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JANUARY – 2026

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 KV Darbhanga - Muzaffarpur circuit - 1	23-01-2026 10:28	23-01-2026 21:28	NIL	NIL	NIL	11:00	Shutdown taken by RTAMC .	100%
400 KV Darbhanga - Muzaffarpur circuit - 2	24-01-2026 09:20	24-01-2026 17:27	NIL	NIL	NIL	08:07	Shutdown taken by RTAMC .	
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	05-01-2026 17:57	06-01-2026 01:31	NIL	NIL	NIL	07:34	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	07-01-2026 10:50	07-01-2026 23:03	NIL	NIL	NIL	12:13	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	08-01-2026 17:52	08-01-2026 23:39	NIL	NIL	NIL	05:47	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	15-01-2026 18:00	15-01-2026 23:05	NIL	NIL	NIL	05:05	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	07-01-2026 19:22	07-01-2026 23:07	NIL	NIL	NIL	03:45	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	09-01-2026 10:53	09-01-2026 23:32	NIL	NIL	NIL	12:39	For voltage regulation.	
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	27-01-2026 13:30	27-01-2026 16:13	NIL	NIL	02:43	NIL	Line tripped in Zone-1, B-Phase Fault, FC:- 14.26kA, FD:- 10.6km. It was found that a high-intensity fire had occurred beneath the transmission line between Tower Nos. 73 to 75. The fire spread over a few square kilometers in the	

Darbhanga-Motihari Transmission Company Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
							grassland area of the Gandak River, which is densely covered with elephant grass. The same is believed to be the probable/Natural calamity cause of the line tripping.E-Mail enclosed for your kind reference	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	NIL TRIPPING							
400KV 80MVAR Line Reactor No.2	27-01-2026 13:30	27-01-2026 16:13	NIL	NIL	02:43	NIL	LR switching with line	
400/132KV 200MVA ICT No.1	NIL TRIPPING							
400/132KV 200MVA ICT No.2	NIL TRIPPING							
Motihari 125MVAR Bus Reactor No.1	01-01-2026 00:00	01-01-2026 01:15	NIL	NIL	NIL	01:15	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	05-01-2026 09:34	06-01-2026 00:40	NIL	NIL	NIL	15:06	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	07-01-2026 19:20	07-01-2026 22:28	NIL	NIL	NIL	03:08	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	08-01-2026 17:56	08-01-2026 23:40	NIL	NIL	NIL	05:44	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	10-01-2026 10:15	10-01-2026 14:49	NIL	NIL	NIL	04:34	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	14-01-2026 19:33	15-01-2026 03:20	NIL	NIL	NIL	07:47	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	04-01-2026 18:52	05-01-2026 01:44	NIL	NIL	NIL	06:52	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	05-01-2026 17:59	06-01-2026 00:44	NIL	NIL	NIL	06:45	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	06-01-2026 10:47	07-01-2026 00:24	NIL	NIL	NIL	13:37	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	07-01-2026 19:24	07-01-2026 23:05	NIL	NIL	NIL	03:41	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	09-01-2026 10:52	09-01-2026 23:33	NIL	NIL	NIL	12:41	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	15-01-2026 18:00	15-01-2026 23:05	NIL	NIL	NIL	05:05	For voltage regulation.	

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL