

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MARCH – 2026

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 KV Darbhanga - Muzaffarpur circuit - 1			NIL TRIPPING					100%
400 KV Darbhanga - Muzaffarpur circuit - 2			NIL TRIPPING					
400/220KV 500MVA ICT No.1			NIL TRIPPING					
400/220KV 500MVA ICT No.2			NIL TRIPPING					
Darbhanga 125 MVar Bus reactor-1	10-03-2026 11:28	20-03-2026 16:39	NIL		NIL	245:11	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-1	25-03-2026 18:50	28-03-2026 08:09	NIL		NIL	61:19	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	11-03-2026 15:27	21-03-2026 13:27	NIL		NIL	238:00	For voltage regulation.	
Darbhanga 125 MVar Bus reactor-2	26-03-2026 19:19	31-03-2026 23:59	NIL		NIL	124:40	For voltage regulation.	
400 kV Motihari - Barh Circuit - 1	10-03-2026 09:11	10-03-2026 18:46	NIL	09:35	NIL	NIL	Shutdown taken by Barh NTPC Barh for Insulator Replacement.	
400 kV Motihari - Barh Circuit - 2	13-03-2026 10:40	13-03-2026 14:54	NIL	04:14	NIL	NIL	Emergency shutdown taken by RTAMC/PGCIL for Line Maintenance.	
400 kV Motihari - Barh Circuit - 2	18-03-2026 10:00	18-03-2026 18:18	NIL	08:18	NIL	NIL	Emergency shutdown taken by RTAMC/PGCIL for Maintenance work.	
400 kV Motihari - Gorakhpur Circuit - 1			NIL TRIPPING					
400 KV Motihari - Gorakhpur Circuit - 2			NIL TRIPPING					

Darbhangha-Motihari Transmission Company Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400KV 80MVAR Line Reactor No.1	10-03-2026 09:11	10-03-2026 18:46	NIL	09:35	NIL	NIL	LR-1 Switching with line (S/D taken by NTPC Barh)	
400KV 80MVAR Line Reactor No.2	13-03-2026 10:40	13-03-2026 14:54	NIL	04:14	NIL	NIL	LR-2 Switching with line (S/D taken by RTAMC/PGCIL)	
400KV 80MVAR Line Reactor No.2	18-03-2026 10:00	18-03-2026 18:18	NIL	08:18	NIL	NIL	LR-2 Switching with line (S/D taken by RTAMC/PGCIL)	
400/132KV 200MVA ICT No.1	NIL TRIPPING							
400/132KV 200MVA ICT No.2	NIL TRIPPING							
Motihari 125MVAR Bus Reactor No.1	10-03-2026 18:38	20-03-2026 16:43	NIL	NIL	NIL	238:05	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	25-03-2026 18:54	31-03-2026 23:59	NIL	NIL	NIL	149:05	For voltage regulation.	

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL