

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOVEMBER – 2025

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 KV Darbhanga - Muzaffarpur circuit - 1			NIL TRIPPING					99.97%
400 KV Darbhanga - Muzaffarpur circuit - 2			NIL TRIPPING					
400/220KV 500MVA ICT No.1			NIL TRIPPING					
400/220KV 500MVA ICT No.2			NIL TRIPPING					
Darbhanga 125 MVar Bus reactor-1			NIL TRIPPING					
Darbhanga 125 MVar Bus reactor-2			NIL TRIPPING					
400 kV Motihari - Barh Circuit - 1	22-11-2025 08:30	22-11-2025 14:00	NIL	05:30	NIL	NIL	Emergency Shutdown taken by RTAMC/PGCIL.	
400 kV Motihari - Barh Circuit - 2	03-11-2025 10:25	03-11-2025 11:55	01:30	NIL	NIL	NIL	Line Tripped due to Malfunctioning of gas density monitor (GD7) of line bay.	
400 kV Motihari - Barh Circuit - 2	22-11-2025 14:08	22-11-2025 18:33	NIL	04:25	NIL	NIL		
400 kV Motihari - Gorakhpur Circuit - 1	22-11-2025 14:29	22-11-2025 18:52	NIL	04:23	NIL	NIL	Emergency Shutdown taken by CPCC(PGCIL).	
400 KV Motihari - Gorakhpur Circuit - 2			NIL TRIPPING					
400KV 80MVAR Line Reactor No.1	22-11-2025 08:30	22-11-2025 14:00	NIL	05:30	NIL	NIL	LR switching with line	
400KV 80MVAR Line Reactor No.2	03-11-2025 10:25	03-11-2025 11:55	01:30	NIL	NIL	NIL	LR switching with line	
400KV 80MVAR Line Reactor No.2	22-11-2025 14:08	22-11-2025 18:33	NIL	04:25	NIL	NIL	LR switching with line	
400/132KV 200MVA ICT No.1			NIL TRIPPING					
400/132KV 200MVA ICT No.2			NIL TRIPPING					
Motihari 125MVAR Bus Reactor No.1			NIL TRIPPING					
Motihari 125MVAR Bus Reactor No.2			NIL TRIPPING					



Darbhanga-Motihari Transmission Company Limited

Corporate Identity Number: U40300MH2012PLC342541

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),
Mumbai - 400098

E: dmtcl@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL