

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCTOBER – 2025

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 KV Darbhanga - Muzaffarpur circuit - 1			NIL TRIPPING					99.979%
400 KV Darbhanga - Muzaffarpur circuit - 2			NIL TRIPPING					
400/220KV 500MVA ICT No.1			NIL TRIPPING					
400/220KV 500MVA ICT No.2			NIL TRIPPING					
Darbhanga 125 MVA Bus reactor-1	01-10-2025 00:00	01-10-2025 07:49	NIL	NIL	NIL	07:49	For voltage regulation.	
Darbhanga 125 MVA Bus reactor-1	07-10-2025 18:43	09-10-2025 07:01	NIL	NIL	NIL	36:18	For voltage regulation.	
Darbhanga 125 MVA Bus reactor-1	09-10-2025 17:56	20-10-2025 10:43	NIL	NIL	NIL	256:47	For voltage regulation.	
Darbhanga 125 MVA Bus reactor-1	24-10-2025 18:00	27-10-2025 10:32	NIL	NIL	NIL	64:32	For voltage regulation.	
400 kV Motihari - Barh Circuit - 1			NIL TRIPPING					
400 kV Motihari - Barh Circuit - 2	08-10-2025 11:34	08-10-2025 14:50	NIL	NIL	NIL	03:16	Emergency Shutdown taken by PGCIL for Rectification of insulator.	
400 kV Motihari - Gorakhpur Circuit - 1			NIL TRIPPING					
400 KV Motihari - Gorakhpur Circuit - 2			NIL TRIPPING					
400KV 80MVAR Line Reactor No.1			NIL TRIPPING					
400KV 80MVAR Line Reactor No.2	08-10-2025 11:34	08-10-2025 14:50	NIL	03:16	NIL	NIL	Emergency Shutdown with line taken by PGCIL for Rectification of insulator.	
400/132KV 200MVA ICT No.1			NIL TRIPPING					
400/132KV 200MVA ICT No.2	04-10-2025 10:44	04-10-2025 15:05	04:21	NIL	NIL		Due to PRV operated (mal-operation).	

Darbhanga-Motihari Transmission Company Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
Motihari 125MVAR Bus Reactor No.1	01-10-2025 00:00	01-10-2025 07:50	NIL	NIL	NIL	07:50	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	07-10-2025 18:40	09-10-2025 07:29	NIL	NIL	NIL	36:49	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	09-10-2025 17:58	13-10-2025 13:06	NIL	NIL	NIL	91:08	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.1	23-10-2025 18:15	25-10-2025 04:56	NIL	NIL	NIL	34:41	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	01-10-2025 00:00	01-10-2025 06:47	NIL	NIL	NIL	06:47	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	08-10-2025 19:48	09-10-2025 07:03	NIL	NIL	NIL	11:15	For voltage regulation.	
Motihari 125MVAR Bus Reactor No.2	24-10-2025 18:00	26-10-2025 13:48	NIL	NIL	NIL	43:48	For voltage regulation.	



Darbhanga-Motihari Transmission Company Limited

Corporate Identity Number: U40300MH2012PLC342541

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),
Mumbai - 400098

E: dmtcl@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL