

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE REACTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF APRIL -2022

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.983%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVAr Bus reactor-1	4/1/2022 0:00	4/20/2022 4:36	NIL	NIL	NIL	460:36	Instructed by ERLDC	
Darbhanga 125 MVAr Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	4/1/2022 16:22	4/1/2022 19:25	NIL	03:03	NIL	NIL	Line shutdown has been taken by RTAMC/PGCIL for Replacement of decamped insulator (Loc.No:- 163)	
400 kV Motihari - Barh Circuit - 2	4/3/2022 9:52	4/3/2022 15:54	NIL	06:02	NIL	NIL	Line shutdown has been taken by RTAMC/PGCIL for Traction machine removal work	
400 kV Motihari - Gorakhpur Circuit - 1	4/3/2022 16:25	4/30/2022 13:45	NIL	NIL	645:20	NIL	Line shutdown as approved by ERPC Agenda Item No. B17 of 186th OCC	
400 KV Motihari - Gorakhpur Circuit - 2	4/3/2022 16:25	4/30/2022 14:26	NIL	NIL	646:01	NIL	Line shutdown as approved by ERPC Agenda Item No. B17 of 186th OCC	
400KV 80MVAR Line Reactor No.1	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.2	4/1/2022 16:22	4/1/2022 19:25	NIL	03:03	NIL	NIL	Line shutdown has been taken by RTAMC/PGCIL for Replacement of decamped insulator (Loc.No:- 163)
400KV 80MVAR Line Reactor No.2	4/3/2022 9:52	4/3/2022 15:54	NIL	06:02	NIL	NIL	Line shutdown has been taken by RTAMC/PGCIL for Traction machine removal work
400/132KV 200MVA ICT No.1	4/13/2022 10:40	4/13/2022 12:38	01:58	NIL	NIL	NIL	To attend hotspot in IV bushing connector ICT 1
400/132KV 200MVA ICT No.2	4/13/2022 12:54	4/13/2022 14:18	01:24	NIL	NIL	NIL	To attend hotspot in IV bushing connector of ICT 2
Motihari 125MVAR Bus Reactor No.1	4/1/2022 0:00	4/2/2022 9:01	NIL	NIL	NIL	33:01	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	4/10/2022 20:46	4/30/2022 11:31	NIL	NIL	NIL	470:45	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	4/1/2022 0:00	4/22/2022 20:12	NIL	NIL	NIL	524:12	Instructed by ERLDC

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL