

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF DEC -2022

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	12/22/2022 13:06	12/22/2022 19:09	NIL	06:03	NIL	NIL	Shutdown taken by RTAMC for replacement of decapped insulator in Muti circuit tower Loc. 13 of 400kV Patna - Barh Ckt - 3.	
400 kV Motihari - Barh Circuit - 1	12/27/2022 10:05	12/27/2022 18:30	NIL	08:25	NIL	NIL	Shutdown taken by RTAMC for Tower insulator cleaning work.	
400 kV Motihari - Barh Circuit - 1	12/28/2022 9:32	12/28/2022 20:10	NIL	10:38	NIL	NIL	Shutdown taken by RTAMC for Tower insulator cleaning work.	
400 kV Motihari - Barh Circuit - 2	12/29/2022 9:29	12/29/2022 17:51	NIL	08:22	NIL	NIL	Shutdown taken by RTAMC for Tower insulator cleaning work.	

Darbhanga-Motihari Transmission Company Limited

400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.1	12/22/2022 13:06	12/22/2022 19:09	NIL	06:03	NIL	NIL	Due to Shutdown taken by RTAMC of 400kV Motihari - Barh Ckt - 1.
400KV 80MVAR Line Reactor No.1	12/27/2022 10:05	12/27/2022 18:30	NIL	08:25	NIL	NIL	Due to Shutdown taken by RTAMC of 400kV Motihari - Barh Ckt - 1.
400KV 80MVAR Line Reactor No.1	12/28/2022 9:32	12/28/2022 20:10	NIL	10:38	NIL	NIL	Due to Shutdown taken by RTAMC of 400kV Motihari - Barh Ckt - 1.
400KV 80MVAR Line Reactor No.2	12/29/2022 9:29	12/29/2022 17:51	NIL	08:22	NIL	NIL	Due to Shutdown taken by RTAMC of 400kV Motihari - Barh Ckt - 2.
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL