

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2022

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	6/9/2022 21:09	6/13/2022 6:43	NIL	NIL	NIL	81:34	Instructed by ERLDC	
Darbhanga 125 MVar Bus reactor-1	6/25/2022 19:39	6/26/2022 8:55	NIL	NIL	NIL	13:16	Instructed by ERLDC	
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	6/14/2022 15:48	6/14/2022 18:36	NIL	02:48	NIL	NIL	Shutdown taken by NTPC Barh.	
400 kV Motihari - Barh Circuit - 1	6/15/2022 15:27	6/15/2022 16:23	NIL	00:56	NIL	NIL	Line tripped due to line fault. Fault current (B-Phase) 1.73kA, Fault Distance-203.4km (Line fault in PGCIL section) _DMTCL LILO Total Ckt Length 38KM.	
400 kV Motihari - Barh Circuit - 2	6/13/2022 17:54	6/14/2022 15:21	NIL	21:27	NIL	NIL	Shutdown has been taken by RTAMC/PGCIL	

Darbhangha-Motihari Transmission Company Limited

400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.1	6/14/2022 15:48	6/14/2022 18:36	NIL	02:48	NIL	NIL	Shutdown taken by NTPC Barh.
400KV 80MVAR Line Reactor No.1	6/15/2022 15:27	6/15/2022 16:23	NIL	00:56	NIL	NIL	Line reactor tripped due to line fault. Fault current (B-Phase) 1.73kA, Fault Distance-203.4km (Line fault in PGCIL section)_DMTCL LILO Total Ckt Length 38KM.
400KV 80MVAR Line Reactor No.2	6/13/2022 17:54	6/14/2022 15:21	NIL	21:27	NIL	NIL	Shutdown has been taken by RTAMC/PGCIL
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	6/8/2022 19:40	6/17/2022 8:48	NIL	NIL	NIL	205:08	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	6/25/2022 22:12	6/26/2022 8:52	NIL	NIL	NIL	10:40	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	6/26/2022 21:18	6/28/2022 7:24	NIL	NIL	NIL	34:06	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	6/2/2022 19:49	6/10/2022 9:18	NIL	NIL	NIL	181:29	Instructed by ERLDC

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL