

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCT -2022

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	10/23/2022 11:38	10/23/2022 11:47	00:09				Line Tripped due to B-phase to earth fault, Fault current IB: 8.64kA, Distance 19.4km, Z-1	99.987%
400 KV Darbhanga - Muzaffarpur circuit - 1	10/23/2022 17:32	10/23/2022 18:45	01:13				E/S/D taken by dmtcl for three trimming jobs from 19km distance. Note: E/S opening time 17:32Hrs. (30-minute delay by remote end/PGCIL)	
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	NIL TRIPPING						
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	10/14/2022 19:18	10/15/2022 13:34	NIL	NIL	NIL	18:16	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL