

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF SEP -2022

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	9/6/2022 23:34	9/11/2022 9:12	NIL	NIL	NIL	105:38	Instructed by ERLDC	
Darbhanga 125 MVar Bus reactor-2	9/1/2022 0:00	9/1/2022 8:01	NIL	NIL	NIL	08:01	Instructed by ERLDC	
Darbhanga 125 MVar Bus reactor-2	9/5/2022 23:21	9/6/2022 8:21	NIL	NIL	NIL	09:00	Instructed by ERLDC	
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	NIL TRIPPING							
400KV 80MVAR Line Reactor No.2	NIL TRIPPING							
400/132KV 200MVA ICT No.1	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	9/1/2022 0:00	9/11/2022 9:12	NIL	NIL	NIL	249:12	Instructed by ERLDC

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL