

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF AUG- 2024

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability	
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)			
400 kV Malerkotla Amritsar - II	29-08-2024	10:15:00	29-08-2024	12:48:00	02:33	NIL	NIL	NIL	Shutdown taken to attend hot spot in Y-phase of Tower no. 170.	99.8601%	
400 kV Malerkotla Amritsar - I	29-08-2024	13:27:00	29-08-2024	14:55:00	01:28	NIL	NIL	NIL	Shutdown taken to attend hot spot in B-phase jumper at Tower no. 95. (We have cleared the line for charging and subsequently code was issued for charging the line by NRLDC at 14:55. but line was actually charged by RTAMC at 17:46 on same day. Time delay for line charging under events beyond our control and grant system availability accordingly. Email communication is attached for reference).		
400 kV Kurukshetra Malerkotla - I					NIL TRIPPING						
400 kV Kurukshetra Malerkotla - II					NIL TRIPPING						

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL