

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF APRIL -2023

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	01-04-2023	00:00:00	01-04-2023	08:14:00	NIL	NIL	NIL	8:14:00	*Continuous Open from 30-03-2023 at 23:57 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.9220%

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	01-04-2023	00:00:00	01-04-2023	09:17:00	NIL	NIL	NIL	9:17:00	*Continuous Open from 31-03-2023 at 21:25 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	01-04-2023	21:33:00	02-04-2023	08:38:00	NIL	NIL	NIL	11:05:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	01-04-2023	21:36:00	02-04-2023	08:40:00	NIL	NIL	NIL	11:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	02-04-2023	21:26:00	03-04-2023	06:34:00	NIL	NIL	NIL	9:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	03-04-2023	00:52:00	03-04-2023	07:02:00	NIL	NIL	NIL	6:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	03-04-2023	21:12:00	04-04-2023	06:52:00	NIL	NIL	NIL	9:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	04-04-2023	01:15:00	04-04-2023	07:01:00	NIL	NIL	NIL	5:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	04-04-2023	21:32:00	05-04-2023	06:28:00	NIL	NIL	NIL	8:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	05-04-2023	21:39:00	06-04-2023	06:41:00	NIL	NIL	NIL	9:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshtetra Malerkotla - I	08-04-2023	13:18:00	10-04-2023	06:17:00	NIL	NIL	NIL	40:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-04-2023	14:12:00	10-04-2023	06:48:00	NIL	NIL	NIL	16:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	10-04-2023	21:33:00	11-04-2023	07:27:00	NIL	NIL	NIL	9:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-04-2023	17:00:00	19-04-2023	19:10:00	02:10	NIL	NIL	0:00:00	Shutdown taken to attend hot spot in Y-phase jumper at Tower no. 180 of Malerkotla Amritsar circuit 1	
400 kV Malerkotla Amritsar - I	23-04-2023	15:33:00	24-04-2023	06:52:00	NIL	NIL	NIL	15:19:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to			Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	23-04-2023	16:47:00	24-04-2023	06:55:00	NIL	NIL	NIL	14:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL