

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF APRIL -2024

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	02-04-2024	21:55:00	03-04-2024	06:37:00	NIL	NIL	NIL	8:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100%
400 kV Malerkotla Amritsar - I	04-04-2024	21:28:00	05-04-2024	08:57:00	NIL	NIL	NIL	11:29:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-04-2024	01:55:00	06-04-2024	09:40:00	NIL	NIL	NIL	7:45:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	13-04-2024	17:10:00	14-04-2024	09:19:00	NIL	NIL	NIL	16:09:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-04-2024	13:32:00	15-04-2024	06:58:00	NIL	NIL	NIL	17:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-04-2024	02:39:00	20-04-2024	06:21:00	NIL	NIL	NIL	3:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	NIL TRIPPING									
400 kV Kurukshetra Malerkotla - II	NIL TRIPPING									
400 kV Malerkotla Amritsar - II	NIL TRIPPING									

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL