

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF DECEMBER – 2025

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	01-12-2025 00:00	01-12-2025 06:51	00:00	00:00	00:00	6:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100.00 %
400 kV Malerkotla Amritsar - I	01-12-2025 03:43	01-12-2025 05:45	00:00	00:00	00:00	2:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	01-12-2025 20:46	02-12-2025 05:39	00:00	00:00	00:00	8:53:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	01-12-2025 21:29	02-12-2025 06:25	00:00	00:00	00:00	8:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-12-2025 22:01	03-12-2025 06:44	00:00	00:00	00:00	8:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	03-12-2025 21:24	04-12-2025 06:20	00:00	00:00	00:00	8:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-12-2025 21:34	04-12-2025 06:02	00:00	00:00	00:00	8:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	04-12-2025 22:28	05-12-2025 07:09	00:00	00:00	00:00	8:41:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-12-2025 01:18	05-12-2025 07:33	00:00	00:00	00:00	6:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-12-2025 20:19	06-12-2025 07:20	00:00	00:00	00:00	11:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - II	05-12-2025 23:15	06-12-2025 07:04	00:00	00:00	00:00	7:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-12-2025 21:30	07-12-2025 08:13	00:00	00:00	00:00	10:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	07-12-2025 21:38	08-12-2025 06:00	00:00	00:00	00:00	8:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	07-12-2025 21:32	08-12-2025 06:16	00:00	00:00	00:00	8:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-12-2025 01:05	09-12-2025 06:13	00:00	00:00	00:00	5:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	09-12-2025 01:11	09-12-2025 06:16	00:00	00:00	00:00	5:05:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-12-2025 21:26	10-12-2025 06:46	00:00	00:00	00:00	9:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	09-12-2025 23:14	10-12-2025 06:56	00:00	00:00	00:00	7:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-12-2025 21:26	11-12-2025 06:59	00:00	00:00	00:00	9:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	10-12-2025 21:45	11-12-2025 07:08	00:00	00:00	00:00	9:23:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	11-12-2025 21:34	12-12-2025 06:44	00:00	00:00	00:00	9:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	12-12-2025 00:13	12-12-2025 06:38	00:00	00:00	00:00	6:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	12-12-2025 21:34	13-12-2025 07:24	00:00	00:00	00:00	9:50:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	12-12-2025 22:50	13-12-2025 07:08	00:00	00:00	00:00	8:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	13-12-2025 21:40	14-12-2025 06:24	00:00	00:00	00:00	8:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	13-12-2025 21:43	14-12-2025 06:47	00:00	00:00	00:00	9:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-12-2025 21:45	15-12-2025 08:43	00:00	00:00	00:00	10:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	14-12-2025 23:41	15-12-2025 07:42	00:00	00:00	00:00	8:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-12-2025 21:35	16-12-2025 06:36	00:00	00:00	00:00	9:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	15-12-2025 21:41	16-12-2025 06:38	00:00	00:00	00:00	8:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-12-2025 21:55	17-12-2025 05:55	00:00	00:00	00:00	8:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	17-12-2025 01:22	17-12-2025 05:50	00:00	00:00	00:00	4:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-12-2025 22:18	18-12-2025 06:51	00:00	00:00	00:00	8:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	17-12-2025 22:57	18-12-2025 07:04	00:00	00:00	00:00	8:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	18-12-2025 21:21	19-12-2025 07:23	00:00	00:00	00:00	10:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	18-12-2025 21:15	19-12-2025 07:39	00:00	00:00	00:00	10:24:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	19-12-2025 20:44	20-12-2025 07:03	00:00	00:00	00:00	10:19:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-12-2025 20:39	20-12-2025 07:10	00:00	00:00	00:00	10:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	20-12-2025 21:39	21-12-2025 07:01	00:00	00:00	00:00	9:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	20-12-2025 21:36	21-12-2025 06:57	00:00	00:00	00:00	9:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	21-12-2025 20:56	22-12-2025 06:32	00:00	00:00	00:00	9:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-12-2025 23:25	22-12-2025 07:32	00:00	00:00	00:00	8:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	22-12-2025 23:23	23-12-2025 08:49	00:00	00:00	00:00	9:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-12-2025 22:39	24-12-2025 06:11	00:00	00:00	00:00	7:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-12-2025 21:41	25-12-2025 06:00	00:00	00:00	00:00	8:19:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	25-12-2025 03:19	25-12-2025 08:27	00:00	00:00	00:00	5:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	25-12-2025 22:08	26-12-2025 06:53	00:00	00:00	00:00	8:45:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-12-2025 00:08	26-12-2025 06:41	00:00	00:00	00:00	6:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-12-2025 21:45	27-12-2025 06:33	00:00	00:00	00:00	8:48:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	27-12-2025 01:38	27-12-2025 06:21	00:00	00:00	00:00	4:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	27-12-2025 23:30	28-12-2025 06:25	00:00	00:00	00:00	6:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	28-12-2025 22:18	29-12-2025 06:26	00:00	00:00	00:00	8:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	29-12-2025 01:37	29-12-2025 06:20	00:00	00:00	00:00	4:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	29-12-2025 22:21	30-12-2025 06:33	00:00	00:00	00:00	8:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	30-12-2025 22:23	31-12-2025 05:45	00:00	00:00	00:00	7:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-12-2025 23:01	31-12-2025 07:12	00:00	00:00	00:00	8:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	31-12-2025 21:22	01-01-2026 00:00	00:00	00:00	00:00	2:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	31-12-2025 22:13	01-01-2026 00:00	00:00	00:00	00:00	1:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL