

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF FEB-2025

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	01-02-2025	00:55:00	01-02-2025	06:41:00	NIL	NIL	NIL	5:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100%
400 kV Malerkotla Amritsar - I	01-02-2025	20:48:00	02-02-2025	06:57:00	NIL	NIL	NIL	10:09:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	02-02-2025	21:38:00	03-02-2025	06:20:00	NIL	NIL	NIL	8:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	02-02-2025	22:42:00	03-02-2025	05:57:00	NIL	NIL	NIL	7:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-02-2025	21:31:00	04-02-2025	06:46:00	NIL	NIL	NIL	9:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	03-02-2025	22:24:00	04-02-2025	06:34:00	NIL	NIL	NIL	8:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	04-02-2025	21:22:00	05-02-2025	06:06:00	NIL	NIL	NIL	8:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	04-02-2025	21:46:00	05-02-2025	05:48:00	NIL	NIL	NIL	8:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	05-02-2025	21:26:00	06-02-2025	07:11:00	NIL	NIL	NIL	9:45:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-02-2025	23:29:00	06-02-2025	07:23:00	NIL	NIL	NIL	7:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	06-02-2025	21:40:00	07-02-2025	06:39:00	NIL	NIL	NIL	8:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	07-02-2025	20:59:00	08-02-2025	05:33:00	NIL	NIL	NIL	8:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	07-02-2025	22:59:00	08-02-2025	05:49:00	NIL	NIL	NIL	6:50:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-02-2025	23:37:00	09-02-2025	05:50:00	NIL	NIL	NIL	6:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	10-02-2025	01:08:00	10-02-2025	05:26:00	NIL	NIL	NIL	4:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-02-2025	18:15:00	11-02-2025	06:22:00	NIL	NIL	NIL	12:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	10-02-2025	22:03:00	11-02-2025	06:14:00	NIL	NIL	NIL	8:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	11-02-2025	23:26:00	12-02-2025	06:04:00	NIL	NIL	NIL	6:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	11-02-2025	23:42:00	12-02-2025	05:40:00	NIL	NIL	NIL	5:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	13-02-2025	22:48:00	14-02-2025	07:51:00	NIL	NIL	NIL	9:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	14-02-2025	21:31:00	15-02-2025	07:23:00	NIL	NIL	NIL	9:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-02-2025	22:54:00	15-02-2025	07:25:00	NIL	NIL	NIL	8:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	15-02-2025	22:17:00	16-02-2025	06:48:00	NIL	NIL	NIL	8:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	15-02-2025	22:04:00	16-02-2025	06:57:00	NIL	NIL	NIL	8:53:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-02-2025	21:15:00	17-02-2025	05:54:00	NIL	NIL	NIL	8:39:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-02-2025	23:34:00	18-02-2025	05:54:00	NIL	NIL	NIL	6:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	18-02-2025	21:27:00	19-02-2025	07:03:00	NIL	NIL	NIL	9:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-02-2025	01:23:00	19-02-2025	06:48:00	NIL	NIL	NIL	5:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	19-02-2025	21:23:00	20-02-2025	07:22:00	NIL	NIL	NIL	9:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-02-2025	00:28:00	20-02-2025	07:03:00	NIL	NIL	NIL	6:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	20-02-2025	21:30:00	21-02-2025	06:57:00	NIL	NIL	NIL	9:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	21-02-2025	21:40:00	22-02-2025	06:14:00	NIL	NIL	NIL	8:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	23-02-2025	01:07:00	23-02-2025	07:00:00	NIL	NIL	NIL	5:53:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	23-02-2025	21:29:00	24-02-2025	06:23:00	NIL	NIL	NIL	8:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	24-02-2025	21:42:00	25-02-2025	05:37:00	NIL	NIL	NIL	7:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-02-2025	22:32:00	25-02-2025	05:49:00	NIL	NIL	NIL	7:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	25-02-2025	21:26:00	26-02-2025	07:07:00	NIL	NIL	NIL	9:41:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	25-02-2025	21:49:00	26-02-2025	06:59:00	NIL	NIL	NIL	9:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	26-02-2025	20:52:00	27-02-2025	06:44:00	NIL	NIL	NIL	9:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	26-02-2025	20:47:00	27-02-2025	06:30:00	NIL	NIL	NIL	9:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	27-02-2025	21:28:00	28-02-2025	07:58:00	NIL	NIL	NIL	10:30:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	27-02-2025	20:54:00	28-02-2025	08:20:00	NIL	NIL	NIL	11:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	28-02-2025	21:39:00	01-03-2025	00:00:00	NIL	NIL	NIL	2:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation. *Continuous Open	
400 kV Malerkotla Amritsar - II	NIL TRIPPING									

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL