

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF FEBRUARY – 2026

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	01-02-2026 00:00	01-02-2026 08:00	00:00	00:00	00:00	8:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.21 %
400 kV Kurukshetra Malerkotla - II	01-02-2026 21:46	02-02-2026 06:20	00:00	00:00	00:00	8:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	01-02-2026 22:09	02-02-2026 06:19	00:00	00:00	00:00	8:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	02-02-2026 21:21	03-02-2026 06:18	00:00	00:00	00:00	8:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-02-2026 21:31	03-02-2026 06:30	00:00	00:00	00:00	8:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-02-2026 22:01	04-02-2026 07:02	00:00	00:00	00:00	9:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	03-02-2026 22:55	04-02-2026 06:35	00:00	00:00	00:00	7:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	04-02-2026 22:56	05-02-2026 06:22	00:00	00:00	00:00	7:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-02-2026 21:56	06-02-2026 06:07	00:00	00:00	00:00	8:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	05-02-2026 23:20	06-02-2026 06:13	00:00	00:00	00:00	6:53:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	06-02-2026 22:42	07-02-2026 06:01	00:00	00:00	00:00	7:19:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-02-2026 22:32	07-02-2026 06:03	00:00	00:00	00:00	7:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-02-2026 02:24	08-02-2026 07:40	00:00	00:00	00:00	5:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	08-02-2026 21:30	09-02-2026 06:55	00:00	00:00	00:00	9:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-02-2026 21:33	10-02-2026 06:11	00:00	00:00	00:00	8:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	10-02-2026 01:45	10-02-2026 05:58	00:00	00:00	00:00	4:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	10-02-2026 22:23	11-02-2026 06:00	00:00	00:00	00:00	7:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-02-2026 23:11	11-02-2026 06:03	00:00	00:00	00:00	6:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	11-02-2026 21:28	12-02-2026 06:45	00:00	00:00	00:00	9:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	11-02-2026 21:26	12-02-2026 06:51	00:00	00:00	00:00	9:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	12-02-2026 21:39	13-02-2026 06:34	00:00	00:00	00:00	8:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	13-02-2026 00:32	13-02-2026 06:30	00:00	00:00	00:00	5:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	13-02-2026 09:39	13-02-2026 20:30	00:00	00:00	00:00	10:51:00	Shut-Down taken by PGCIL for Retrofitting of electromechanical BB relay with numerical Relay work at Amritsar Substation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	13-02-2026 22:04	14-02-2026 07:22	00:00	00:00	00:00	9:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	13-02-2026 23:03	14-02-2026 06:18	00:00	00:00	00:00	7:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-02-2026 10:20	14-02-2026 18:32	00:00	00:00	00:00	8:12:00	Shut-Down taken by PGCIL for Retrofitting of electromechanical BB relay with numerical Relay work at Amritsar Substation.	
400 kV Malerkotla Amritsar - II	14-02-2026 21:47	15-02-2026 06:42	00:00	00:00	00:00	8:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	14-02-2026 23:29	15-02-2026 05:43	00:00	00:00	00:00	6:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-02-2026 17:09	16-02-2026 06:50	00:00	00:00	00:00	13:41:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	15-02-2026 21:49	16-02-2026 06:34	00:00	00:00	00:00	8:45:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	17-02-2026 00:27	17-02-2026 06:54	00:00	00:00	00:00	6:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-02-2026 22:30	18-02-2026 06:04	00:00	00:00	00:00	7:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	18-02-2026 21:17	19-02-2026 06:01	00:00	00:00	00:00	8:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	18-02-2026 22:11	19-02-2026 06:03	00:00	00:00	00:00	7:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	19-02-2026 22:28	20-02-2026 05:55	00:00	00:00	00:00	7:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-02-2026 23:05	20-02-2026 06:05	00:00	00:00	00:00	7:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	20-02-2026 21:35	21-02-2026 05:58	00:00	00:00	00:00	8:23:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-02-2026 23:36	21-02-2026 06:07	00:00	00:00	00:00	6:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	21-02-2026 22:15	22-02-2026 06:53	00:00	00:00	00:00	8:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-02-2026 22:20	22-02-2026 07:02	00:00	00:00	00:00	8:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	22-02-2026 21:28	23-02-2026 06:39	00:00	00:00	00:00	9:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	22-02-2026 21:31	23-02-2026 06:37	00:00	00:00	00:00	9:06:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	23-02-2026 22:54	24-02-2026 07:01	00:00	00:00	00:00	8:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-02-2026 22:59	24-02-2026 06:45	00:00	00:00	00:00	7:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-02-2026 22:21	25-02-2026 06:32	00:00	00:00	00:00	8:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	24-02-2026 23:55	25-02-2026 06:53	00:00	00:00	00:00	6:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	25-02-2026 21:39	26-02-2026 05:03	00:00	00:00	00:00	7:24:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-02-2026 00:03	26-02-2026 05:20	00:00	00:00	00:00	5:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	26-02-2026 08:31	26-02-2026 18:59	10:28	00:00	00:00	0:00:00	Shutdown taken for attending shutdown type observation such as tightening/fixing of N&B for Jumper, Hardware Fittings & Accessories etc.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - II	26-02-2026 21:17	27-02-2026 05:53	00:00	00:00	00:00	8:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-02-2026 21:56	27-02-2026 05:50	00:00	00:00	00:00	7:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	27-02-2026 08:17	27-02-2026 19:46	11:29	00:00	00:00	0:00:00	Shutdown taken for attending shutdown type observation such as tightening/fixing of N&B for Jumper, Hardware Fittings & Accessories etc.	
400 kV Malerkotla Amritsar - I	27-02-2026 21:43	28-02-2026 05:42	00:00	00:00	00:00	7:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	28-02-2026 23:54	01-03-2026 00:00	00:00	00:00	00:00	0:06:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL