

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JAN'22

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	01-01-2022	00:00:00	01-01-2022	06:42:00	NIL	NIL	NIL	6:42:00	*Continuous Open from 31-12-2021 at 21:22 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100%
400 kV Malerkotla Amritsar - II	01-01-2022	21:31:00	02-01-2022	06:39:00	NIL	NIL	NIL	9:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-01-2022	23:21:00	04-01-2022	06:47:00	NIL	NIL	NIL	31:26:00	Hand Tripped as per NRLDC Instruction, Due to	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									voltage regulation.	
400 kV Malerkotla Amritsar - I	04-01-2022	22:00:00	05-01-2022	07:14:00	NIL	NIL	NIL	9:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-01-2022	19:15:00	06-01-2022	06:50:00	NIL	NIL	NIL	11:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	06-01-2022	23:00:00	07-01-2022	09:32:00	NIL	NIL	NIL	10:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	07-01-2022	21:21:00	09-01-2022	10:37:00	NIL	NIL	NIL	37:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-01-2022	22:24:00	10-01-2022	09:35:00	NIL	NIL	NIL	11:11:00	Hand Tripped as per NRLDC Instruction, Due to	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									voltage regulation.	
400 kV Malerkotla Amritsar - I	10-01-2022	21:55:00	11-01-2022	08:42:00	NIL	NIL	NIL	10:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	13-01-2022	22:14:00	14-01-2022	09:13:00	NIL	NIL	NIL	10:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	14-01-2022	21:48:00	16-01-2022	09:20:00	NIL	NIL	NIL	35:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-01-2022	23:50:00	18-01-2022	07:39:00	NIL	NIL	NIL	31:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duratio of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	19-01-2022	20:57:00	20-01-2022	06:53:00	NIL	NIL	NIL	9:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-01-2022	21:04:00	21-01-2022	06:43:00	NIL	NIL	NIL	9:39:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	22-01-2022	23:53:00	23-01-2022	08:44:00	NIL	NIL	NIL	8:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	23-01-2022	21:26:00	24-01-2022	08:34:00	NIL	NIL	NIL	11:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-01-2022	21:27:00	25-01-2022	07:05:00	NIL	NIL	NIL	9:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	25-01-2022	21:52:00	26-01-2022	07:27:00	NIL	NIL	NIL	9:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	27-01-2022	00:28:00	27-01-2022	07:31:00	NIL	NIL	NIL	7:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	28-01-2022	21:27:00	29-01-2022	07:47:00	NIL	NIL	NIL	10:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	29-01-2022	21:28:00	30-01-2022	08:06:00	NIL	NIL	NIL	10:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-01-2022	22:22:00	31-01-2022	05:50:00	NIL	NIL	NIL	7:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage	Restoration	Duratio of Outage Attributable to				Reason of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	NIL TRIPPING							
400 kV Kurukshetra Malerkotla - II	NIL TRIPPING							

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III



NRSS XXXI (B) Transmission Limited

Corporate Identity Number: U40106MH2013PLC342540

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),

Mumbai - 400098

E: nrss31b@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



NRSS XXXI (B) Transmission Limited

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL