

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JAN-2025

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	01-01-2025	00:00:00	01-01-2025	06:00:00	NIL	NIL	NIL	6:00:00	*Continuous Open from 31-12-2024 at 22:37 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.7787%
400 kV Malerkotla Amritsar - I	01-01-2025	00:00:00	01-01-2025	06:17:00	NIL	NIL	NIL	6:17:00	*Continuous Open from 31-12-2024 at 21:29 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	01-01-2025	20:56:00	02-01-2025	08:20:00	NIL	NIL	NIL	11:24:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	01-01-2025	21:27:00	02-01-2025	08:39:00	NIL	NIL	NIL	11:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-01-2025	21:55:00	03-01-2025	06:17:00	NIL	NIL	NIL	8:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	02-01-2025	22:01:00	03-01-2025	05:49:00	NIL	NIL	NIL	7:48:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-01-2025	21:33:00	04-01-2025	09:36:00	NIL	NIL	NIL	12:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	04-01-2025	00:11:00	04-01-2025	08:13:00	NIL	NIL	NIL	8:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	04-01-2025	21:34:00	05-01-2025	08:10:00	NIL	NIL	NIL	10:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	04-01-2025	23:59:00	05-01-2025	08:11:00	NIL	NIL	NIL	8:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-01-2025	23:35:00	06-01-2025	07:01:00	NIL	NIL	NIL	7:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	06-01-2025	01:11:00	06-01-2025	06:47:00	NIL	NIL	NIL	5:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-01-2025	21:52:00	07-01-2025	05:56:00	NIL	NIL	NIL	8:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	07-01-2025	21:20:00	08-01-2025	06:37:00	NIL	NIL	NIL	9:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	07-01-2025	22:00:00	08-01-2025	05:45:00	NIL	NIL	NIL	7:45:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-01-2025	21:02:00	09-01-2025	06:14:00	NIL	NIL	NIL	9:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	09-01-2025	00:12:00	09-01-2025	05:27:00	NIL	NIL	NIL	5:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	09-01-2025	11:30:00	09-01-2025	18:42:00	NIL	NIL	NIL	7:12:00	Shut-Down taken by PGCIL for maintenance work of bay (410-411) of 400 kV Malerkotla Amritsar CKT-II at Amritsar Substation.	
400 kV Malerkotla Amritsar - I	09-01-2025	22:41:00	10-01-2025	05:50:00	NIL	NIL	NIL	7:09:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-01-2025	11:20:00	10-01-2025	22:30:00	NIL	NIL	NIL	11:10:00	Shut-Down taken by PGCIL for maintenance work of bay (413-414) of 400 kV Malerkotla Amritsar CKT-I at Amritsar Substation.	
400 kV Kurukshetra Malerkotla - I	11-01-2025	00:32:00	11-01-2025	07:21:00	NIL	NIL	NIL	6:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	11-01-2025	22:00:00	12-01-2025	09:12:00	NIL	NIL	NIL	11:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	11-01-2025	22:17:00	12-01-2025	07:31:00	NIL	NIL	NIL	9:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	12-01-2025	21:55:00	13-01-2025	06:30:00	NIL	NIL	NIL	8:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	12-01-2025	22:05:00	13-01-2025	06:34:00	NIL	NIL	NIL	8:29:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	13-01-2025	22:43:00	14-01-2025	05:53:00	NIL	NIL	NIL	7:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	14-01-2025	21:45:00	15-01-2025	06:13:00	NIL	NIL	NIL	8:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	14-01-2025	22:16:00	15-01-2025	06:22:00	NIL	NIL	NIL	8:06:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-01-2025	22:41:00	16-01-2025	06:30:00	NIL	NIL	NIL	7:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	15-01-2025	22:48:00	16-01-2025	05:47:00	NIL	NIL	NIL	6:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	16-01-2025	12:57:00	16-01-2025	19:47:00	06:50	NIL	NIL	NIL	Line tripped on Phase to Ground Fault (Y-N), Dist. 87.88km, Fault current 3.7kA from Malerkotla end and Dist. 44.11km, Fault current 7.03kA from Kurukshetra end. Line was tripped due to Jumper Snap.	
400 kV Kurukshetra Malerkotla - I	16-01-2025	21:24:00	17-01-2025	06:13:00	NIL	NIL	NIL	8:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-01-2025	21:51:00	17-01-2025	06:13:00	NIL	NIL	NIL	8:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-01-2025	21:41:00	18-01-2025	06:33:00	NIL	NIL	NIL	8:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	17-01-2025	23:28:00	18-01-2025	05:37:00	NIL	NIL	NIL	6:09:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	18-01-2025	21:33:00	19-01-2025	05:30:00	NIL	NIL	NIL	7:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	18-01-2025	23:19:00	19-01-2025	06:24:00	NIL	NIL	NIL	7:05:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-01-2025	21:03:00	20-01-2025	06:42:00	NIL	NIL	NIL	9:39:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	20-01-2025	21:26:00	21-01-2025	06:26:00	NIL	NIL	NIL	9:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-01-2025	22:02:00	22-01-2025	06:21:00	NIL	NIL	NIL	8:19:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	21-01-2025	22:27:00	22-01-2025	06:09:00	NIL	NIL	NIL	7:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-01-2025	21:32:00	24-01-2025	06:21:00	NIL	NIL	NIL	8:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	24-01-2025	01:14:00	24-01-2025	06:09:00	NIL	NIL	NIL	4:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	25-01-2025	22:45:00	26-01-2025	05:46:00	NIL	NIL	NIL	7:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	25-01-2025	23:04:00	26-01-2025	06:00:00	NIL	NIL	NIL	6:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-01-2025	21:54:00	27-01-2025	06:57:00	NIL	NIL	NIL	9:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	26-01-2025	21:53:00	27-01-2025	07:20:00	NIL	NIL	NIL	9:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	27-01-2025	23:05:00	28-01-2025	06:23:00	NIL	NIL	NIL	7:18:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL