

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JULY- 2024

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	03-07-2024	23:17:00	04-07-2024	01:50:00	02:33	NIL	NIL	NIL	Shutdown Taken to attend/rectification of hotspot in R-phase jumper at tower no. 4 of Malerkotla – Amritsar CKT-I	99.7601%
400 kV Kurukshetra Malerkotla - I	19-07-2024	15:09:00	19-07-2024	19:49:00	04:40	NIL	NIL	NIL	R Phase Jumper Broken. Emergency shutdown for replacement of broken R-phase jumper at Tower no. 295 of Kurukshetra Malerkotla CKT-I.	
400 kV Kurukshetra Malerkotla - II	NIL TRIPPING									
400 kV Malerkotla Amritsar - II	NIL TRIPPING									

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL