

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE-2022

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	NIL TRIPPING						NIL	100%
400 kV Kurukshetra Malerkotla - II	NIL TRIPPING						NIL	
400 kV Malerkotla Amritsar - I	NIL TRIPPING						NIL	
400 kV Malerkotla Amritsar - II	NIL TRIPPING						NIL	

S

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III



NRSS XXXI (B) Transmission Limited

Corporate Identity Number: U40106MH2013PLC342540

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),

Mumbai - 400098

E: nrss31b@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



NRSS XXXI (B) Transmission Limited

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL