

# NRSS XXXI (B) Transmission Limited

## SCHEDULE I

### AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2023

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	01-06-2023	00:26:00	02-06-2023	10:18:00	NIL	NIL	NIL	33:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.88%
400 kV Malerkotla Amritsar - I	10-06-2023	16:22:00	10-06-2023	19:41:00	03:19	NIL	NIL	0:00:00	Phase to earth fault B-N Line tripped on B-N fault. FLR Malerkotla: 12km, 14.1kA, Amritsar: 115.9km, 3kA. Line was tripped due to tree which is eliminated by cutting..	

# NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to			Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)		
400 kV Malerkotla Amritsar - II	14-06-2023	21:43:00	14-06-2023	22:31:00	NIL	00:48	NIL	0:00:00	Upon on transient B-N fault, line remained charged post successful auto reclosure operation from PGCIL Amritsar S/s end but remained open from PGCIL Malerkotla S/s end, as auto reclosure operation could not be successful from PGCIL Malerkotla S/s end. To get clarified the events which lead to non-operation of auto-reclosure from PGCIL Malerkotla S/s end, we also requested NRLDC in order to avoid any such events in future.
400 kV Kurukshetra Malerkotla - I	NIL TRIPPING								
400 kV Kurukshetra Malerkotla - II	NIL TRIPPING								

# NRSS XXXI (B) Transmission Limited

## SCHEDULE II

### ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

# NRSS XXXI (B) Transmission Limited

## SCHEDULE III

### DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL