

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MARCH-2025

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	01-03-2025	00:00:00	01-03-2025	07:09:00	NIL	NIL	NIL	7:09:00	*Continuous Open from 28-02-2025 at 21:39 hrs. Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.2705%
400 kV Kurukshetra Malerkotla - II	01-03-2025	03:41:00	01-03-2025	06:54:00	NIL	NIL	NIL	3:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	01-03-2025	23:04:00	02-03-2025	07:05:00	NIL	NIL	NIL	8:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	01-03-2025	23:54:00	02-03-2025	08:26:00	NIL	NIL	NIL	8:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	02-03-2025	17:05:00	03-03-2025	06:47:00	NIL	NIL	NIL	13:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-03-2025	17:03:00	03-03-2025	07:01:00	NIL	NIL	NIL	13:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	03-03-2025	18:27:00	03-03-2025	22:33:00	NIL	NIL	NIL	4:06:00	Emergency shutdown taken by PGCIL Kurukshetra for reconnecting the HF cable from 400kV B-phase CVT to LMU at Kurukshetra.	
400 kV Kurukshetra Malerkotla - II	03-03-2025	22:33:00	04-03-2025	16:09:00	NIL	NIL	NIL	17:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-03-2025	22:46:00	04-03-2025	08:03:00	NIL	NIL	NIL	9:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	04-03-2025	16:09:00	04-03-2025	18:48:00	NIL	NIL	NIL	2:39:00	Emergency shutdown taken by PGCIL Kurukshetra for attending SF6 gas low pressure in Isolator GIS Compartment (B-phase G42) at Kurukshetra(PG).	
400 kV Kurukshetra Malerkotla - I	04-03-2025	22:14:00	05-03-2025	05:56:00	NIL	NIL	NIL	7:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	04-03-2025	22:05:00	05-03-2025	05:54:00	NIL	NIL	NIL	7:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-03-2025	21:49:00	06-03-2025	06:53:00	NIL	NIL	NIL	9:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-03-2025	21:16:00	07-03-2025	05:58:00	NIL	NIL	NIL	8:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	06-03-2025	21:25:00	07-03-2025	05:45:00	NIL	NIL	NIL	8:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	07-03-2025	21:19:00	08-03-2025	06:15:00	NIL	NIL	NIL	8:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	07-03-2025	21:18:00	08-03-2025	06:02:00	NIL	NIL	NIL	8:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-03-2025	09:39:00	10-03-2025	20:42:00	11:03	NIL	NIL	NIL	Shutdown taken for attending shutdown type observation such as tightening/fixing of N&B for Jumper, Hardware Fittings & Accessories etc.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	11-03-2025	09:37:00	11-03-2025	19:31:00	09:54	NIL	NIL	NIL	Shutdown taken for attending shutdown type observation such as tightening/fixing of N&B for Jumper, Hardware Fittings & Accessories etc.	
400 kV Malerkotla Amritsar - I	13-03-2025	21:47:00	14-03-2025	06:44:00	NIL	NIL	NIL	8:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	14-03-2025	18:35:00	15-03-2025	07:27:00	NIL	NIL	NIL	12:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	14-03-2025	21:25:00	15-03-2025	07:07:00	NIL	NIL	NIL	9:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	15-03-2025	20:53:00	16-03-2025	07:25:00	NIL	NIL	NIL	10:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-03-2025	21:00:00	16-03-2025	07:27:00	NIL	NIL	NIL	10:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	16-03-2025	21:29:00	17-03-2025	05:44:00	NIL	NIL	NIL	8:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	17-03-2025	21:07:00	18-03-2025	05:38:00	NIL	NIL	NIL	8:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	18-03-2025	22:59:00	19-03-2025	05:37:00	NIL	NIL	NIL	6:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	19-03-2025	21:31:00	20-03-2025	07:31:00	NIL	NIL	NIL	10:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-03-2025	23:37:00	21-03-2025	06:47:00	NIL	NIL	NIL	7:10:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	21-03-2025	21:43:00	22-03-2025	06:11:00	NIL	NIL	NIL	8:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	28-03-2025	21:58:00	29-03-2025	06:57:00	NIL	NIL	NIL	8:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	29-03-2025	21:30:00	30-03-2025	06:46:00	NIL	NIL	NIL	9:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-03-2025	21:32:00	31-03-2025	06:20:00	NIL	NIL	NIL	8:48:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	31-03-2025	21:26:00	01-04-2025	00:00:00	NIL	NIL	NIL	2:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation. *Continuous Open	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL