

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MARCH – 2026

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	01-03-2026 00:00	01-03-2026 07:15	00:00	00:00	00:00	7:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.01%
400 kV Malerkotla Amritsar - I	01-03-2026 00:36	01-03-2026 06:58	00:00	00:00	00:00	6:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	01-03-2026 21:03	02-03-2026 06:52	00:00	00:00	00:00	9:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	01-03-2026 21:34	02-03-2026 06:59	00:00	00:00	00:00	9:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	02-03-2026 21:19	03-03-2026 06:10	00:00	00:00	00:00	8:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	03-03-2026 23:19	04-03-2026 07:40	00:00	00:00	00:00	8:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	04-03-2026 19:09	05-03-2026 07:03	00:00	00:00	00:00	11:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	04-03-2026 21:26	05-03-2026 07:06	00:00	00:00	00:00	9:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-03-2026 21:44	06-03-2026 06:28	00:00	00:00	00:00	8:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	06-03-2026 23:11	07-03-2026 06:01	00:00	00:00	00:00	6:50:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	07-03-2026 23:23	08-03-2026 07:20	00:00	00:00	00:00	7:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	07-03-2026 23:34	08-03-2026 07:18	00:00	00:00	00:00	7:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-03-2026 23:11	09-03-2026 06:26	00:00	00:00	00:00	7:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	09-03-2026 21:38	10-03-2026 06:49	00:00	00:00	00:00	9:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-03-2026 21:59	10-03-2026 06:48	00:00	00:00	00:00	8:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	10-03-2026 21:51	11-03-2026 08:25	00:00	00:00	00:00	10:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	11-03-2026 21:33	12-03-2026 06:01	00:00	00:00	00:00	8:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	12-03-2026 21:36	13-03-2026 07:31	00:00	00:00	00:00	9:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	13-03-2026 21:58	14-03-2026 06:26	00:00	00:00	00:00	8:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-03-2026 03:30	14-03-2026 06:28	00:00	00:00	00:00	2:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	14-03-2026 21:21	15-03-2026 07:02	00:00	00:00	00:00	9:41:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-03-2026 23:11	15-03-2026 06:47	00:00	00:00	00:00	7:36:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	15-03-2026 13:35	16-03-2026 06:55	00:00	00:00	00:00	17:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	15-03-2026 21:29	16-03-2026 07:02	00:00	00:00	00:00	9:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-03-2026 21:52	17-03-2026 06:44	00:00	00:00	00:00	8:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	17-03-2026 22:22	18-03-2026 06:42	00:00	00:00	00:00	8:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-03-2026 22:27	18-03-2026 06:34	00:00	00:00	00:00	8:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	18-03-2026 20:50	19-03-2026 07:05	00:00	00:00	00:00	10:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	18-03-2026 22:27	19-03-2026 06:04	00:00	00:00	00:00	7:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	19-03-2026 21:47	20-03-2026 08:46	00:00	00:00	00:00	10:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	19-03-2026 21:49	20-03-2026 08:43	00:00	00:00	00:00	10:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-03-2026 21:19	21-03-2026 06:35	00:00	00:00	00:00	9:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	20-03-2026 21:53	21-03-2026 06:40	00:00	00:00	00:00	8:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-03-2026 22:05	22-03-2026 06:48	00:00	00:00	00:00	8:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	22-03-2026 01:45	22-03-2026 06:53	00:00	00:00	00:00	5:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	22-03-2026 13:26	23-03-2026 06:47	00:00	00:00	00:00	17:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	22-03-2026 13:21	23-03-2026 07:00	00:00	00:00	00:00	17:39:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-03-2026 23:54	24-03-2026 07:25	00:00	00:00	00:00	7:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-03-2026 21:51	25-03-2026 06:29	00:00	00:00	00:00	8:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	25-03-2026 01:23	25-03-2026 06:35	00:00	00:00	00:00	5:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	25-03-2026 16:30	25-03-2026 22:17	05:47	00:00	00:00	00:00	Line was tripped on FAULT TYPE: Y Phase to Ground Fault FAULT CURRENT: 19.513 kA LOCATION: 3.697km from Malerkotla End and Fault Current: 2.44 KA Location: 129.8 km from Kurukshetra end. We have completed the ground patrolling of the line for relevant area but did not find any fault in the line. Line was successfully charged at 22:17 hrs. For assessing the exact cause of tripping of line, we conducted the tower top patrolling of line on next day i.e. on 26-03-2026 for relevant area. During Tower Top Patrolling, we observed that Kite thread was entangled on OPGW towards Top Y-Phase of CKT-I Conductor (Photographs & Video enclosed for reference) at Tower no. 373. For removing Kite Thread, we have taken the emergency shutdown on 26-03-2026.	
400 kV Kurukshetra Malerkotla - II	25-03-2026 22:48	26-03-2026 06:51	00:00	00:00	00:00	8:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	26-03-2026 16:41	26-03-2026 18:05	01:24	00:00	00:00	0:00:00	Emergency Shutdown taken for removal of Kite Thread from tower no. 373, which was entangled between VD of OPGW & Top Y-Phase conductor.	
400 kV Kurukshetra Malerkotla - II	26-03-2026 22:57	27-03-2026 07:00	00:00	00:00	00:00	8:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	29-03-2026 22:19	30-03-2026 06:49	00:00	00:00	00:00	8:30:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-03-2026 09:45	30-03-2026 20:11	10:26	00:00	00:00	0:00:00	Shutdown taken for attending shutdown type observation such as tightening/fixing of N&B for Jumper, Hardware Fittings & Accessories etc.	
400 kV Malerkotla Amritsar - I	30-03-2026 21:38	31-03-2026 06:39	00:00	00:00	00:00	9:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	30-03-2026 22:18	31-03-2026 06:34	00:00	00:00	00:00	8:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	31-03-2026 09:17	31-03-2026 20:31	11:14	00:00	00:00	0:00:00	Shutdown taken for attending shutdown type observation such as tightening/fixing of N&B for Jumper, Hardware Fittings & Accessories etc.	
400 kV Malerkotla Amritsar - I	31-03-2026 21:55	01-04-2026 00:00	00:00	00:00	00:00	2:05:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	31-03-2026 21:25	01-04-2026 00:00	00:00	00:00	00:00	2:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL