

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2022

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	19-05-2022	10:06:00	19-05-2022	18:05:00	NIL	NIL	NIL	7:59:00	Shut-Down taken by PGCIL for maintenance work of bay (416 & 417) of 400 kV Malerkotla Amritsar CKT-II at Malerkotla Substation.	99.774%
400 kV Kurukshetra Malerkotla - I	20-05-2022	09:50:00	20-05-2022	17:06:00	NIL	NIL	NIL	7:16:00	Shut-Down taken by PGCIL for maintenance work of bay (418) of 400 kV Kurukshetra Malerkotla CKT-I	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
									at Malerkotla Substation.	
400 kV Kurukshetra Malerkotla - II	23-05-2022	05:29:00	24-05-2022	11:25:00	NIL	NIL	NIL	29:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-05-2022	10:19:00	23-05-2022	16:49:00	NIL	NIL	NIL	6:30:00	Shut-Down taken by PGCIL for maintenance work of bay (413 & 414) of 400 kV Malerkotla Amritsar CKT-I at Malerkotla Substation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System Constraint/Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	28-05-2022	20:51:00	29-05-2022	03:49:00	6:58:00	NIL	NIL	NIL	line was tripped on R & B-N fault, (FLR Malrkotla: 86.97 km, 5.84 kA), (FLR Kurukshetra: 50.17 km, Ir 8.6 kA, Ib 9.5 kA). Line was tripped due to inclement weather condition.	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL