

# NRSS XXXI (B) Transmission Limited

## SCHEDULE I

### AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2023

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - I	03-05-2023	00:48:00	03-05-2023	06:31:00	NIL	NIL	NIL	5:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	99.8122%
400 kV Kurukshetra Malerkotla - II	08-05-2023	08:04:00	08-05-2023	20:45:00	NIL	NIL	NIL	12:41:00	Shut-Down taken by PGCIL for GIB erection for ICT-3 commissioning at Kurukshetra Substation..	
400 kV Kurukshetra Malerkotla - II	18-05-2023	00:17:00	18-05-2023	02:22:00	NIL	NIL	02:05	0:00:00	Line tripped on R-B to N fault. FLR Malerkotla:- 0.4 Km , IR 11 KA & IB 13 KA. Line was tripped due to inclement weather condition.	

# NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	18-05-2023	00:19:00	18-05-2023	02:31:00	02:12	NIL	NIL	0:00:00	Line tripped on R-N Fault. FLR Malerkotla:- 0.1 Km & IR 18 KA. Line was tripped due to inclement weather condition.	
400 kV Kurukshetra Malerkotla - II	18-05-2023	02:22:00	18-05-2023	10:09:00	NIL	NIL	NIL	7:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	18-05-2023	02:31:00	18-05-2023	08:31:00	NIL	NIL	NIL	6:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	29-05-2023	04:25:00	29-05-2023	08:05:00	NIL	NIL	NIL	3:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

# NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	29-05-2023	16:00:00	29-05-2023	17:21:00	01:21	NIL	NIL	0:00:00	Line tripped on Y phase to N Fault. FLR Malerkotla: Y-N, 85.4 KM, FC- 3.8 KA. FLR Kurukshetra: Y-N, 46.03 KM, FC- 7.75 KA. Line was tripped due to inclement weather condition.	
400 kV Kurukshetra Malerkotla - I	29-05-2023	21:15:00	30-05-2023	08:05:00	NIL	NIL	NIL	10:50:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	NIL TRIPPING									

# NRSS XXXI (B) Transmission Limited

## SCHEDULE II

### ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

# NRSS XXXI (B) Transmission Limited

## SCHEDULE III

### DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹ )
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL