

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOVEMBER – 2025

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	01-11-2025 20:16	02-11-2025 07:28	00:00	00:00	00:00	11:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100.00 %
400 kV Kurukshetra Malerkotla - II	01-11-2025 23:46	02-11-2025 06:40	00:00	00:00	00:00	6:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	02-11-2025 17:19	03-11-2025 06:46	00:00	00:00	00:00	13:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	02-11-2025 22:34	03-11-2025 06:48	00:00	00:00	00:00	8:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	04-11-2025 20:51	05-11-2025 09:16	00:00	00:00	00:00	12:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	04-11-2025 20:39	05-11-2025 09:10	00:00	00:00	00:00	12:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	05-11-2025 22:54	06-11-2025 06:46	00:00	00:00	00:00	7:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	06-11-2025 20:35	07-11-2025 06:09	00:00	00:00	00:00	9:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	07-11-2025 00:01	07-11-2025 06:35	00:00	00:00	00:00	6:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	07-11-2025 21:25	08-11-2025 07:37	00:00	00:00	00:00	10:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - II	07-11-2025 21:27	08-11-2025 08:07	00:00	00:00	00:00	10:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	08-11-2025 21:53	09-11-2025 06:51	00:00	00:00	00:00	8:58:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	08-11-2025 21:52	09-11-2025 07:30	00:00	00:00	00:00	9:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	09-11-2025 20:22	10-11-2025 06:56	00:00	00:00	00:00	10:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	09-11-2025 20:28	10-11-2025 06:11	00:00	00:00	00:00	9:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	10-11-2025 21:26	11-11-2025 07:03	00:00	00:00	00:00	9:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	10-11-2025 21:45	11-11-2025 05:56	00:00	00:00	00:00	8:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	11-11-2025 20:21	12-11-2025 07:04	00:00	00:00	00:00	10:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	12-11-2025 00:04	12-11-2025 06:37	00:00	00:00	00:00	6:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	12-11-2025 23:18	13-11-2025 07:21	00:00	00:00	00:00	8:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	12-11-2025 23:31	13-11-2025 07:18	00:00	00:00	00:00	7:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	13-11-2025 21:28	14-11-2025 06:44	00:00	00:00	00:00	9:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	13-11-2025 21:53	14-11-2025 06:45	00:00	00:00	00:00	8:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	14-11-2025 21:05	15-11-2025 06:42	00:00	00:00	00:00	9:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	15-11-2025 22:04	16-11-2025 08:20	00:00	00:00	00:00	10:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	16-11-2025 21:52	17-11-2025 07:47	00:00	00:00	00:00	9:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	17-11-2025 22:10	18-11-2025 07:35	00:00	00:00	00:00	9:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	17-11-2025 22:13	18-11-2025 07:57	00:00	00:00	00:00	9:44:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	18-11-2025 21:01	19-11-2025 06:49	00:00	00:00	00:00	9:48:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	19-11-2025 21:38	20-11-2025 06:51	00:00	00:00	00:00	9:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	20-11-2025 00:05	20-11-2025 08:02	00:00	00:00	00:00	7:57:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	20-11-2025 20:19	21-11-2025 06:50	00:00	00:00	00:00	10:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-11-2025 23:05	21-11-2025 06:57	00:00	00:00	00:00	7:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	21-11-2025 21:40	22-11-2025 05:47	00:00	00:00	00:00	8:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-11-2025 21:42	22-11-2025 07:41	00:00	00:00	00:00	9:59:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-11-2025 02:41	23-11-2025 06:13	00:00	00:00	00:00	3:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - II	23-11-2025 03:17	23-11-2025 08:39	00:00	00:00	00:00	5:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	23-11-2025 21:25	24-11-2025 06:59	00:00	00:00	00:00	9:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	23-11-2025 22:34	24-11-2025 06:47	00:00	00:00	00:00	8:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	24-11-2025 21:32	25-11-2025 07:37	00:00	00:00	00:00	10:05:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	24-11-2025 21:31	25-11-2025 07:45	00:00	00:00	00:00	10:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	25-11-2025 20:41	26-11-2025 07:56	00:00	00:00	00:00	11:15:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	25-11-2025 20:41	26-11-2025 08:00	00:00	00:00	00:00	11:19:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	26-11-2025 22:29	27-11-2025 05:54	00:00	00:00	00:00	7:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-11-2025 22:17	27-11-2025 06:19	00:00	00:00	00:00	8:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	27-11-2025 21:23	28-11-2025 07:44	00:00	00:00	00:00	10:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	28-11-2025 00:05	28-11-2025 07:51	00:00	00:00	00:00	7:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	28-11-2025 22:56	29-11-2025 07:23	00:00	00:00	00:00	8:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	28-11-2025 23:16	29-11-2025 06:06	00:00	00:00	00:00	6:50:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - II	29-11-2025 20:36	30-11-2025 06:50	00:00	00:00	00:00	10:14:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	30-11-2025 21:21	01-12-2025 00:00	00:00	00:00	00:00	2:39:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL