

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCT -2023

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - II	03-10-2023	01:21:00	03-10-2023	08:42:00	NIL	NIL	NIL	7:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100%
400 kV Malerkotla Amritsar - I	04-10-2023	00:21:00	04-10-2023	10:59:00	NIL	NIL	NIL	10:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	04-10-2023	23:15:00	05-10-2023	08:42:00	NIL	NIL	NIL	9:27:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	10-10-2023	01:01:00	10-10-2023	07:21:00	NIL	NIL	NIL	6:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	12-10-2023	21:48:00	13-10-2023	09:18:00	NIL	NIL	NIL	11:30:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	13-10-2023	22:01:00	14-10-2023	08:41:00	NIL	NIL	NIL	10:40:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	13-10-2023	22:24:00	14-10-2023	09:20:00	NIL	NIL	NIL	10:56:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	14-10-2023	22:03:00	15-10-2023	08:50:00	NIL	NIL	NIL	10:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	16-10-2023	21:23:00	17-10-2023	06:53:00	NIL	NIL	NIL	9:30:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	16-10-2023	22:33:00	17-10-2023	06:40:00	NIL	NIL	NIL	8:07:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	17-10-2023	21:09:00	18-10-2023	06:32:00	NIL	NIL	NIL	9:23:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	18-10-2023	22:48:00	19-10-2023	06:49:00	NIL	NIL	NIL	8:01:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	18-10-2023	23:07:00	19-10-2023	06:39:00	NIL	NIL	NIL	7:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	19-10-2023	20:53:00	20-10-2023	09:17:00	NIL	NIL	NIL	12:24:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	20-10-2023	01:15:00	20-10-2023	09:19:00	NIL	NIL	NIL	8:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	20-10-2023	21:52:00	21-10-2023	10:20:00	NIL	NIL	NIL	12:28:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-10-2023	21:27:00	21-10-2023	09:39:00	NIL	NIL	NIL	12:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	21-10-2023	21:14:00	22-10-2023	08:56:00	NIL	NIL	NIL	11:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	21-10-2023	22:22:00	22-10-2023	09:04:00	NIL	NIL	NIL	10:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	22-10-2023	21:39:00	23-10-2023	09:39:00	NIL	NIL	NIL	12:00:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	22-10-2023	22:18:00	23-10-2023	09:50:00	NIL	NIL	NIL	11:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	23-10-2023	21:08:00	24-10-2023	07:40:00	NIL	NIL	NIL	10:32:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	23-10-2023	21:03:00	24-10-2023	06:38:00	NIL	NIL	NIL	9:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	24-10-2023	19:47:00	25-10-2023	08:24:00	NIL	NIL	NIL	12:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	24-10-2023	21:06:00	25-10-2023	06:39:00	NIL	NIL	NIL	9:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	25-10-2023	20:53:00	26-10-2023	06:30:00	NIL	NIL	NIL	9:37:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	26-10-2023	02:48:00	26-10-2023	07:35:00	NIL	NIL	NIL	4:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	26-10-2023	21:15:00	27-10-2023	07:01:00	NIL	NIL	NIL	9:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-10-2023	21:33:00	27-10-2023	06:20:00	NIL	NIL	NIL	8:47:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	27-10-2023	21:27:00	28-10-2023	09:56:00	NIL	NIL	NIL	12:29:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	27-10-2023	21:59:00	28-10-2023	07:33:00	NIL	NIL	NIL	9:34:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	28-10-2023	21:47:00	29-10-2023	09:35:00	NIL	NIL	NIL	11:48:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	28-10-2023	23:41:00	29-10-2023	09:33:00	NIL	NIL	NIL	9:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	29-10-2023	17:29:00	30-10-2023	07:15:00	NIL	NIL	NIL	13:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Kurukshetra Malerkotla - II	29-10-2023	20:40:00	30-10-2023	07:29:00	NIL	NIL	NIL	10:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	30-10-2023	20:28:00	31-10-2023	06:30:00	NIL	NIL	NIL	10:02:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	30-10-2023	22:03:00	31-10-2023	06:41:00	NIL	NIL	NIL	8:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	31-10-2023	20:52:00	01-11-2023	00:00:00	NIL	NIL	NIL	3:08:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation. *Continuous Open	

NRSS XXXI (B) Transmission Limited

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time		Date & Time		Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 kV Malerkotla Amritsar - I	31-10-2023	21:18:00	01-11-2023	00:00:00	NIL	NIL	NIL	2:42:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation. *Continuous Open	

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

NRSS XXXI (B) Transmission Limited

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL