

NRSS XXXI (B) Transmission Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCTOBER – 2025

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	06-10-2025 21:13	07-10-2025 09:39	00:00	00:00	00:00	12:26:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	100.00 %
400 kV Kurukshetra Malerkotla - I	06-10-2025 22:27	07-10-2025 09:13	00:00	00:00	00:00	10:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	08-10-2025 00:58	08-10-2025 09:47	00:00	00:00	00:00	8:49:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	08-10-2025 01:01	10-10-2025 07:40	00:00	00:00	00:00	54:39:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	09-10-2025 01:41	10-10-2025 07:19	00:00	00:00	00:00	29:38:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	12-10-2025 23:12	13-10-2025 06:16	00:00	00:00	00:00	7:04:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	13-10-2025 00:38	13-10-2025 06:29	00:00	00:00	00:00	5:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	13-10-2025 22:21	14-10-2025 07:24	00:00	00:00	00:00	9:03:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	14-10-2025 21:30	15-10-2025 06:51	00:00	00:00	00:00	9:21:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	15-10-2025 22:09	18-10-2025 09:15	00:00	00:00	00:00	59:06:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Malerkotla Amritsar - I	16-10-2025 22:21	17-10-2025 07:07	00:00	00:00	00:00	8:46:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	19-10-2025 23:49	20-10-2025 09:14	00:00	00:00	00:00	9:25:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	19-10-2025 23:58	20-10-2025 09:18	00:00	00:00	00:00	9:20:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	20-10-2025 21:34	21-10-2025 08:51	00:00	00:00	00:00	11:17:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	20-10-2025 21:37	21-10-2025 08:59	00:00	00:00	00:00	11:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	21-10-2025 21:14	22-10-2025 08:36	00:00	00:00	00:00	11:22:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	21-10-2025 21:26	22-10-2025 09:09	00:00	00:00	00:00	11:43:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	22-10-2025 20:50	23-10-2025 09:03	00:00	00:00	00:00	12:13:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	22-10-2025 21:27	23-10-2025 09:02	00:00	00:00	00:00	11:35:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	23-10-2025 21:26	24-10-2025 07:17	00:00	00:00	00:00	9:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	23-10-2025 21:47	24-10-2025 07:20	00:00	00:00	00:00	9:33:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	24-10-2025 21:01	25-10-2025 07:30	00:00	00:00	00:00	10:29:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - II	25-10-2025 01:30	25-10-2025 08:41	00:00	00:00	00:00	7:11:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	

NRSS XXXI (B) Transmission Limited

ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% AVAILABILITY
	DATE TIME	DATE TIME	Interstate Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Kurukshetra Malerkotla - I	25-10-2025 20:58	26-10-2025 08:49	00:00	00:00	00:00	11:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	26-10-2025 22:24	27-10-2025 08:15	00:00	00:00	00:00	9:51:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	28-10-2025 00:10	28-10-2025 08:26	00:00	00:00	00:00	8:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	28-10-2025 00:21	28-10-2025 08:16	00:00	00:00	00:00	7:55:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	28-10-2025 20:15	29-10-2025 07:31	00:00	00:00	00:00	11:16:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	28-10-2025 21:13	29-10-2025 07:05	00:00	00:00	00:00	9:52:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	29-10-2025 22:39	30-10-2025 07:51	00:00	00:00	00:00	9:12:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - I	30-10-2025 01:03	30-10-2025 07:57	00:00	00:00	00:00	6:54:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Malerkotla Amritsar - I	30-10-2025 22:03	31-10-2025 07:34	00:00	00:00	00:00	9:31:00	Hand Tripped as per NRLDC Instruction, Due to voltage regulation.	
400 kV Kurukshetra Malerkotla - II	NO OUTAGE							

NRSS XXXI (B) Transmission Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL