

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF APR -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.992%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	4/24/2023 14:25	4/24/2023 15:03	00:38	NIL	NIL	NIL	Emergency S/D taken by DMTCL	
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVAr Bus reactor-1	4/8/2023 19:16	4/9/2023 13:24	NIL	NIL	NIL	18:08	Instructed by ERLDC	
Darbhanga 125 MVAr Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	4/5/2023 9:51	4/5/2023 16:35	NIL	06:44	NIL	NIL	Emergency S/D Taken by NTPC to attend Hotspot of Line Isolator	
400 kV Motihari - Barh Circuit - 2	4/13/2023 8:37	4/13/2023 20:00	NIL	11:23	NIL	NIL	S/D Taken by RTAMC to clean the Polluted Insulator Strings	
400 kV Motihari - Barh Circuit - 2	4/14/2023 8:42	4/14/2023 19:35	NIL	10:53	NIL	NIL	S/D Taken by RTAMC to clean the Polluted Insulator Strings	
400 kV Motihari - Barh Circuit - 2	4/15/2023 8:11	4/15/2023 19:43	NIL	11:32	NIL	NIL	S/D Taken by RTAMC to clean the Polluted Insulator Strings	
400 kV Motihari - Gorakhpur Circuit - 1	4/20/2023 9:49	4/20/2023 19:12	NIL	09:23	NIL	NIL	S/D Taken by RTAMC to replace the damaged insulators.	
400 KV Motihari - Gorakhpur Circuit - 2	4/21/2023 9:16	4/21/2023 20:17	NIL	11:01	NIL	NIL	S/D Taken by RTAMC to replace the damaged insulators.	

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	4/5/2023 9:51	4/5/2023 16:35	NIL	06:44	NIL	NIL	Emergency S/D Taken by NTPC to attend Hotspot of Line Isolator
400KV 80MVAR Line Reactor No.2	4/13/2023 8:37	4/13/2023 20:00	NIL	11:23	NIL	NIL	S/D Taken by RTAMC to clean the Polluted Insulator Strings
400KV 80MVAR Line Reactor No.2	4/14/2023 8:42	4/14/2023 19:35	NIL	10:53	NIL	NIL	S/D Taken by RTAMC to clean the Polluted Insulator Strings
400KV 80MVAR Line Reactor No.2	4/15/2023 8:11	4/15/2023 19:43	NIL	11:32	NIL	NIL	S/D Taken by RTAMC to clean the Polluted Insulator Strings
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	4/8/2023 19:13	4/9/2023 12:01	NIL	NIL	NIL	16:48	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	4/9/2023 19:04	4/23/2023 8:10	NIL	NIL	NIL	325:06	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	4/26/2023 19:20	4/30/2023 13:10	NIL	NIL	NIL	89:50	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	4/8/2023 19:17	4/9/2023 13:23	NIL	NIL	NIL	18:06	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	4/11/2023 21:13	4/23/2023 9:08	NIL	NIL	NIL	275:55	Instructed by ERLDC

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL