

Darbhangha-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF AUG -2021

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhangha 125MVAR Bus Reactor No.1	8/1/2021 0:00	8/8/2021 6:14	NIL	NIL	NIL	174:14	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.1	8/10/2021 22:25	8/14/2021 8:48	NIL	NIL	NIL	82:23	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.1	8/14/2021 19:19	8/23/2021 6:18	NIL	NIL	NIL	202:59	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.1	8/24/2021 20:51	8/25/2021 7:39	NIL	NIL	NIL	10:48	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.1	8/26/2021 21:45	8/31/2021 0:00	NIL	NIL	NIL	98:15	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.2	8/1/2021 22:44	8/9/2021 6:59	NIL	NIL	NIL	176:15	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.2	8/9/2021 21:14	8/10/2021 5:36	NIL	NIL	NIL	08:22	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.2	8/14/2021 18:47	8/17/2021 6:23	NIL	NIL	NIL	59:36	Voltage regulation	
Darbhangha 125MVAR Bus Reactor No.2	8/24/2021 22:53	8/26/2021 6:49	NIL	NIL	NIL	31:56	Voltage regulation	
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							

Darbhangha-Motihari Transmission Company Limited

400 kV Motihari - Barh Circuit - 1	NIL TRIPPING						
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	8/2/2021 20:17	8/7/2021 6:15	NIL	NIL	NIL	105:58	Voltage regulation
Motihari 125MVAR Bus Reactor No.2	8/5/2021 20:26	8/8/2021 5:46	NIL	NIL	NIL	57:20	Voltage regulation

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL