

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE REACTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF FEB -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	2/13/2023 10:00	2/13/2023 19:25	NIL	09:25	NIL	NIL	Shutdown Taken by PGCIL Muzaffarpur for AMP work.	99.645%
400 KV Darbhanga - Muzaffarpur circuit - 2	2/10/2023 9:55	2/10/2023 19:53	NIL	09:58	NIL	NIL	Shutdown Taken by PGCIL Muzaffarpur for AMP work.	
400/220KV 500MVA ICT No.1	2/9/2023 9:18	2/9/2023 18:18	09:00	NIL	NIL	NIL	S/D Taken by DMTCL for AMP work.	
400/220KV 500MVA ICT No.2	2/11/2023 8:26	2/11/2023 17:05	08:39	NIL	NIL	NIL	S/D Taken by DMTCL for AMP work.	
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	2/16/2023 17:15	2/16/2023 18:59	01:44	NIL	NIL	NIL	Emergency S/D Taken by DMTCL for attending Hotspot Work at LA.	
400 kV Motihari - Barh Circuit - 1	2/16/2023 9:13	2/17/2023 19:12	NIL	33:59	NIL	NIL	S/D Taken by NTPC for AMP work.	
400 kV Motihari - Barh Circuit - 2	2/11/2023 17:05	2/11/2023 23:00	NIL	05:55	NIL	NIL	S/D Taken by RTAMC due to replacement of faulty insulator.	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						No Outage	
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						No Outage	
400KV 80MVAR Line Reactor No.1	2/16/2023 9:13	2/17/2023 19:12	NIL	33:59	NIL	NIL	Reactor Off with Line due to S/D Taken by NTPC for AMP work.	

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.2	2/11/2023 17:05	2/11/2023 23:00	NIL	05:55	NIL	NIL	Reactor Off with Line due to S/D Taken by RTAMC due to replacement of faulty insulator.
400/132KV 200MVA ICT No.1	2/1/2023 10:10	2/1/2023 20:59	10:49	NIL	NIL	NIL	S/D Taken by DMTCL for AMP work.
400/132KV 200MVA ICT No.2	2/3/2023 8:14	2/3/2023 16:37	08:23	NIL	NIL	NIL	S/D Taken by DMTCL for AMP work.
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL