

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF FEB -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	2/2/2024 15:19	2/2/2024 20:08	NIL	NIL	04:49	NIL	Natural calamity- Line trip due to fire under the transmission line	
400 kV Motihari - Barh Circuit - 1	2/29/2024 9:54	2/29/2024 18:33	NIL	08:39		NIL	Shutdown taken by RTAMC	
400 kV Motihari - Barh Circuit - 2	2/2/2024 15:19	2/2/2024 20:38	NIL	NIL	5:19	NIL	Natural calamity- Line trip due to fire under the transmission line	
400 kV Motihari - Barh Circuit - 2	2/12/2024 8:06	2/12/2024 13:22	NIL	05:16	NIL	NIL	Shutdown taken by RTAMC	
400 kV Motihari - Barh Circuit - 2	2/19/2024 8:22	2/20/2024 18:21	NIL	33:59	NIL	NIL	Shutdown taken by RTAMC	
400 kV Motihari - Gorakhpur Circuit - 1	2/2/2024 15:19	2/2/2024 22:49	NIL	NIL	07:30	NIL	Natural calamity- Line trip due to fire under the transmission line	
400 KV Motihari - Gorakhpur Circuit - 2	2/2/2024 15:19	2/2/2024 23:46	NIL	NIL	08:27	NIL	Natural calamity- Line trip due to fire under the transmission line	
400KV 80MVAR Line Reactor No.1	2/2/2024 15:19	2/2/2024 20:08	NIL		4:49	NIL	Natural calamity- Line trip due to fire under the transmission line	

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	2/29/2024 9:54	2/29/2024 18:33	NIL	08:39	NIL	NIL	Shutdown taken by RTAMC
400KV 80MVAR Line Reactor No.2	2/2/2024 15:19	2/2/2024 20:38	NIL	NIL	5:19	NIL	Natural calamity- Line trip due to fire under the transmission line
400KV 80MVAR Line Reactor No.2	2/12/2024 8:06	2/12/2024 13:22	NIL	05:16	NIL	NIL	Shutdown taken by RTAMC
400KV 80MVAR Line Reactor No.2	2/19/2024 8:22	2/20/2024 18:21	NIL	33:59	NIL	NIL	Shutdown taken by RTAMC
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL