

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JAN -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission on Licensee	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.900%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	1/11/2023 10:27	1/11/2023 18:37	NIL	08:10	NIL	NIL	Shutdown Taken by RTAMC/PGCIL.	
400 kV Motihari - Barh Circuit - 1	1/23/2023 2:25	1/23/2023 2:55	00:30	NIL	NIL	NIL	Line Tripped due Ph-Ph fault Distance: 8.9 KM Fault Current: -IA: 11.75kA & Ib: 12.15kA, Zone-1	
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING							
400 kV Motihari - Gorakhpur Circuit - 1	1/31/2023 9:49	1/31/2023 19:49	NIL	10:00	NIL	NIL	Shutdown Taken by Gorakhpur PGCIL.	
400 KV Motihari - Gorakhpur Circuit - 2	1/13/2023 16:09	1/13/2023 20:16	NIL	04:07	NIL	NIL	Shutdown Taken by Gorakhpur PGCIL.	
400KV 80MVAR Line Reactor No.1	1/11/2023 10:27	1/11/2023 18:37	NIL	08:10	NIL	NIL	Shutdown taken by RTAMC of 400kV Motihari - Barh Ckt - 1.	
400KV 80MVAR Line Reactor No.1	1/23/2023 2:25	1/23/2023 2:55	00:30				LR trip with line.	
400KV 80MVAR Line Reactor No.2	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

400/132KV 200MVA ICT No.1	NIL TRIPPING	
400/132KV 200MVA ICT No.2	NIL TRIPPING	
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING	
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING	

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL