

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JAN -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	1/19/2024 10:29	1/19/2024 18:51	NIL	08:22	NIL	NIL	Shutdown taken by RTMC for AMP work	100%
400 KV Darbhanga - Muzaffarpur circuit - 2	1/23/2024 10:11	1/23/2024 17:38	NIL	07:27	NIL	NIL	Shutdown taken by RTMC for AMP work	
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	1/13/2024 7:59	1/13/2024 17:55	NIL	09:56	NIL	NIL	Shutdown taken by RTAMC for insulator replacement	
400 kV Motihari - Barh Circuit - 2	1/15/2024 8:35	1/15/2024 16:34	NIL	07:59	NIL	NIL	Shutdown taken by RTAMC for insulator replacement	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	1/13/2024 7:59	1/13/2024 17:55	NIL	09:56	NIL	NIL	Shutdown taken by RTAMC for insulator replacement	
400KV 80MVAR Line Reactor No.2	1/15/2024 8:35	1/15/2024 16:34	NIL	07:59	NIL	NIL	Shutdown taken by RTAMC for insulator replacement	
400/132KV 200MVA ICT No.1	NIL TRIPPING							
400/132KV 200MVA ICT No.2	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING	
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING	

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL