

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JULY -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVAR Bus reactor-1	7/24/2023 21:31	7/29/2023 15:17	NIL	NIL	NIL	113:46	Due to Voltage Regulation	
Darbhanga 125 MVAR Bus reactor-2	7/28/2023 22:30	7/29/2023 15:31	NIL	NIL	NIL	17:01	Due to Voltage Regulation	
400 kV Motihari - Barh Circuit - 1	7/13/2023 17:09	7/13/2023 20:51	NIL	3:42	NIL	NIL	Shutdown taken by RTAMC for rectification of decapped pilot insulator at Loc no 222.	
400 kV Motihari - Barh Circuit - 1	7/25/2023 6:46	7/25/2023 14:39	NIL	7:53	NIL	NIL	Shutdown taken by RTAMC for rectification of decapped insulator at MC 14.	
400 kV Motihari - Barh Circuit - 2	7/25/2023 7:15	7/25/2023 15:39	NIL	8:24	NIL	NIL	Shutdown taken by RTAMC for rectification of decapped insulator at MC 14.	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	7/13/2023 17:09	7/13/2023 20:51	NIL	3:42	NIL	NIL	Shutdown taken by RTAMC for rectification of decapped pilot insulator at Loc no 222.	

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	7/25/2023 6:46	7/25/2023 14:39	NIL	7:53	NIL	NIL	Shutdown taken by RTAMC for rectification of decapped insulator at MC 14..
400KV 80MVAR Line Reactor No.2	7/25/2023 7:15	7/25/2023 15:39	NIL	8:24	NIL	NIL	Shutdown taken by RTAMC for rectification of decapped insulator at MC 14.
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	7/9/2023 19:46	7/14/2023 15:46	NIL	NIL	NIL	116:00	Due to Voltage Regulation
Motihari 125MVAR Bus Reactor No.1	7/23/2023 22:12	7/29/2023 7:40	NIL	NIL	NIL	129:28	Due to Voltage Regulation
Motihari 125MVAR Bus Reactor No.1	7/29/2023 22:41	7/31/2023 23:59	NIL	NIL	NIL	49:18	Due to Voltage Regulation
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL