

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2021

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.772%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125MVAR Bus Reactor No.1	01.06.2021 00:00	01.06.2021 05:51	NIL	NIL	NIL	05:51	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.1	02.06.2021 20:34	09.06.2021 05:25	NIL	NIL	NIL	152:51	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.1	09.06.2021 19:59	20.06.2021 08:55	NIL	NIL	NIL	252:56	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.1	21.06.2021 21:52	30.06.2021 00:00	NIL	NIL	NIL	194:08	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	01.06.2021 00:00	01.06.2021 05:53	NIL	NIL	NIL	05:53	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	02.06.2021 20:54	09.06.2021 05:36	NIL	NIL	NIL	152:42	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	23.06.2021 20:58	30.06.2021 00:00	NIL	NIL	NIL	147:02	Instructed by ERLDC	
400 kV Motihari - Barh Circuit - 2	6/26/2021 11:48	6/26/2021 18:11	NIL	06:23	NIL	NIL	S/D Taken by RTAMC for damaged insulator replacement	
400 kV Motihari - Barh Circuit - 1	6/2/2021 20:39	6/2/2021 21:17	00:38	NIL	NIL	NIL	Line tripped due to Ph-Earth fault (Conductor snapped from quad)	

Darbhangha-Motihari Transmission Company Limited

400 kV Motihari - Barh Circuit - 1	6/2/2021 21:17	6/4/2021 0:04	26:47	NIL	NIL	NIL	Line tripped due to Ph-Earth fault (Conductor snapped from quad)
400 kV Motihari - Barh Circuit - 1	6/9/2021 9:05	6/10/2021 17:54		32:49	NIL	NIL	S/D Taken by NTPC Barh for AM & Testing
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	6/26/2021 11:48	6/26/2021 18:11	NIL	06:23	NIL	NIL	S/D Taken by RTAMC for damaged insulator replacement
400KV 80MVAR Line Reactor No.1	6/2/2021 20:39	6/2/2021 21:17	00:38	NIL	NIL	NIL	
400KV 80MVAR Line Reactor No.1	6/2/2021 21:17	6/4/2021 0:04	26:47	NIL	NIL	NIL	
400KV 80MVAR Line Reactor No.1	6/9/2021 9:05	6/10/2021 17:54	NIL	32:49	NIL	NIL	S/D Taken by NTPC Barh for AM & Testing
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	6/3/2021 21:04	6/4/2021 6:20	NIL	NIL	NIL	09:16	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	6/23/2021 20:58	6/25/2021 6:00	NIL	NIL	NIL	33:02	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	6/3/2021 21:11	6/4/2021 6:28	NIL	NIL	NIL	09:17	Instructed by ERLDC

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL