

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF JUNE -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							97.743%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVar Bus reactor-1	6/15/2023 21:56	6/27/2023 15:51	NIL	NIL	NIL	281:55	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 2	6/5/2023 9:36	6/5/2023 18:51	NIL	9:15	NIL	NIL	Shutdown taken by NTPC for Line Bays AMP work	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	NIL TRIPPING							
400KV 80MVAR Line Reactor No.2	6/5/2023 9:36	6/5/2023 18:51	NIL	9:15	NIL	NIL	Shutdown taken by NTPC for Line Bays AMP work	
400/132KV 200MVA ICT No.1	6/1/2023 0:00	6/19/2023 23:04	455:04	NIL	NIL	NIL	Tripped due to Differential Protection. Fault Current - B Phase - 1 KA (HV)	
400/132KV 200MVA ICT No.2	NIL TRIPPING							

Darbhanga-Motihari Transmission Company Limited

Motihari 125MVAR Bus Reactor No.1	6/1/2023 0:00	6/10/2023 7:18	NIL	NIL	NIL	223:18	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	6/4/2023 20:06	6/14/2023 12:48	NIL	NIL	NIL	232:42	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	6/16/2023 20:51	6/21/2023 7:40	NIL	NIL	NIL	106:49	Instructed by ERLDC

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL