

Darbhangha-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAR -2024

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	3/31/2024 13:46	3/31/2024 14:06	00:20				DMTCL Line Tripped in Zone-1, B-Phase fault	99.997%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhangha 125 MVar Bus reactor-1	NIL TRIPPING							
Darbhangha 125 MVar Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	3/15/2024 9:40	3/15/2024 18:17	NIL	08:37	NIL	NIL	Shutdown taken by RTAMC	
400 kV Motihari - Barh Circuit - 1	3/28/2024 6:59	3/28/2024 19:03	NIL	12:04	NIL	NIL	Shutdown taken by RTAMC	
400 kV Motihari - Barh Circuit - 1	3/31/2024 4:41	3/31/2024 6:57	NIL	02:16	NIL	NIL	DT Received from Barh End	
400 kV Motihari - Barh Circuit - 2	3/11/2024 8:42	3/12/2024 18:32	NIL	33:50	NIL	NIL	Shutdown taken by NTPC Barh	
400 kV Motihari - Barh Circuit - 2	3/27/2024 8:32	3/27/2024 13:39	NIL	05:07	NIL	NIL	Shutdown taken by RTAMC	
400 kV Motihari - Barh Circuit - 2	3/28/2024 6:57	3/28/2024 19:05	NIL	12:08	NIL	NIL	Shutdown taken by RTAMC	
400 kV Motihari - Barh Circuit - 2	3/31/2024 4:41	3/31/2024 7:24	NIL	02:43	NIL	NIL	DT Received from Barh End	
400 kV Motihari - Gorakhpur Circuit - 1	3/18/2024 11:20	3/18/2024 20:18	NIL	08:58	NIL	NIL	Shutdown taken by Gorakhpur PGCIL	
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							

Darbhangha-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	3/15/2024 9:40	3/15/2024 18:17	NIL	08:37	NIL	NIL	Shutdown taken by RTAMC
400KV 80MVAR Line Reactor No.1	3/28/2024 6:59	3/28/2024 19:03	NIL	12:04	NIL	NIL	Shutdown taken by RTAMC
400KV 80MVAR Line Reactor No.1	3/31/2024 4:41	3/31/2024 6:57	NIL	02:16	NIL	NIL	DT Received from NTPC Barh End
400KV 80MVAR Line Reactor No.2	3/11/2024 8:42	3/12/2024 18:32	NIL	33:50	NIL	NIL	Shutdown taken by NTPC Barh
400KV 80MVAR Line Reactor No.2	3/27/2024 8:32	3/27/2024 13:39	NIL	05:07	NIL	NIL	Shutdown taken by RTAMC
400KV 80MVAR Line Reactor No.2	3/28/2024 6:57	3/28/2024 19:05	NIL	12:08	NIL	NIL	Shutdown taken by RTAMC
400KV 80MVAR Line Reactor No.2	3/31/2024 4:41	3/31/2024 7:24	NIL	02:43	NIL	NIL	DT Received from NTPC Barh End
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL