

# Darbhanga-Motihari Transmission Company Limited

## SCHEDULE I

### AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MARCH -2022

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability		
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)				
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING									
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING									
400/220KV 500MVA ICT No.1	NIL TRIPPING									
400/220KV 500MVA ICT No.2	NIL TRIPPING									
Darbhanga 125 MVAr Bus reactor-1	3/26/2022 17:22	3/31/2022 23:59	NIL	NIL	NIL	126:37	Instructed by ERLDC	100%		
Darbhanga 125 MVAr Bus reactor-2	NIL TRIPPING									
400 kV Motihari - Barh Circuit - 1	3/5/2022 8:17	3/30/2022 22:21	NIL	NIL	614:04	NIL	Line shutdown As approved by ERPC Agenda Item No. B17 of 186th OCC			
400 kV Motihari - Barh Circuit - 1	3/31/2022 7:24	3/31/2022 11:30	NIL	04:06	NIL	NIL	Line tripped due to DTT received from remote end (Barh NTPC)			
400 kV Motihari - Barh Circuit - 2	3/13/2022 9:37	3/30/2022 22:04	NIL	NIL	420:27	NIL	Line shutdown As approved by ERPC Agenda Item No. B17 of 186th OCC			
400 kV Motihari - Barh Circuit - 2	3/30/2022 22:05	3/30/2022 22:29	NIL	00:24	NIL	NIL	Line tripped due to line Earth fault. Fault distance-161.2kM in PGCIL Section (DMTCL LILO Section 38KM Only)			
400 kV Motihari - Barh Circuit - 2	3/30/2022 22:29	3/31/2022 12:16	NIL	13:47	NIL	NIL	Line tripped due to DTT received from remote end (Barh NTPC)			
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING									
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING									
400KV 80MVAR Line Reactor No.1	3/5/2022 8:17	3/30/2022 22:21	NIL	NIL	NIL	614:04	Instructed by ERLDC			

# Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.1	3/31/2022 7:24	3/31/2022 11:30	NIL	04:06	NIL	NIL	Line tripped due to DTT received from remote end (Barh NTPC)
400KV 80MVAR Line Reactor No.2	3/13/2022 9:37	3/30/2022 22:04	NIL		NIL	420:27	Instructed by ERLDC
400KV 80MVAR Line Reactor No.2	3/30/2022 22:05	3/30/2022 22:29	NIL	00:24	NIL	NIL	Line tripped due to DTT received from remote end (Barh NTPC)
400KV 80MVAR Line Reactor No.2	3/30/2022 22:29	3/31/2022 12:16	NIL	13:47	NIL	NIL	Line tripped due to DTT received from remote end (Barh NTPC)
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	3/13/2022 18:56	3/26/2022 13:08	NIL	NIL	NIL	306:12	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	3/26/2022 19:18	3/31/2022 23:59	NIL	NIL	NIL	124:41	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	3/26/2022 19:13	3/31/2022 23:59	NIL	NIL	NIL	124:46	Instructed by ERLDC

# Darbhanga-Motihari Transmission Company Limited

## SCHEDULE II

### ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

## SCHEDULE III

### DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL