

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2021

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							99.989%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125MVAR Bus Reactor No.1	5/15/2021 22:19	5/16/2021 7:08	NIL	NIL	NIL	08:49	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	5/15/2021 22:21	5/16/2021 7:15	NIL	NIL	NIL	08:54	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.1	5/22/2021 21:54	5/23/2021 7:55	NIL	NIL	NIL	10:01	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	5/22/2021 22:00	5/23/2021 8:00	NIL	NIL	NIL	10:00	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.1	5/23/2021 21:29	5/25/2021 7:55	NIL	NIL	NIL	34:26	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	5/24/2021 19:33	5/25/2021 7:59	NIL	NIL	NIL	12:26	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.1	5/31/2021 22:32	5/31/2021 23:59	NIL	NIL	NIL	01:27	Instructed by ERLDC	
Darbhanga 125MVAR Bus Reactor No.2	5/31/2021 22:34	5/31/2021 23:59	NIL	NIL	NIL	01:25	Instructed by ERLDC	
400 kV Motihari - Barh Circuit - 2	5/28/2021 6:04	5/29/2021 12:31	NIL	NIL	NIL	30:27	Instructed by ERLDC	
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING						No Outage	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						No Outage	

Darbhangha-Motihari Transmission Company Limited

400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						No Outage
400KV 80MVAR Line Reactor No.2	5/28/2021 6:05	5/28/2021 6:12	NIL	NIL	NIL	00:07	Instructed by ERLDC
400KV 80MVAR Line Reactor No.2	5/29/2021 12:25	5/29/2021 12:31	NIL	NIL	NIL	00:06	Instructed by ERLDC
400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.1	5/23/2021 7:02	5/23/2021 8:36	01:34	NIL	NIL	NIL	Emergency Shutdown for tightness of IV Bushing connector & Jumper replacement
400/132KV 200MVA ICT No.2	5/23/2021 9:08	5/23/2021 9:50	00:42	NIL	NIL	NIL	Emergency Shutdown for tightness of IV Bushing connector
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL