

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF MAY -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING						No Outage	99.725%
400 KV Darbhanga - Muzaffarpur circuit - 2	5/11/2023 8:59	5/11/2023 10:51	01:52	NIL	NIL	NIL	Emergency shutdown taken for attending Conductor rectification.	
400/220KV 500MVA ICT No.1	NIL TRIPPING						No Outage	
400/220KV 500MVA ICT No.2	NIL TRIPPING						No Outage	
Darbhanga 125 MVar Bus reactor-1	5/7/2023 23:38	5/8/2023 8:35	NIL	NIL	NIL	08:57	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-1	5/9/2023 19:28	5/11/2023 7:38	NIL	NIL	NIL	36:10	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-1	5/13/2023 22:21	5/18/2023 6:30	NIL	NIL	NIL	104:09	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-1	5/22/2023 19:40	5/23/2023 6:15	NIL	NIL	NIL	10:35	Due to Voltage Regulation	
Darbhanga 125 MVar Bus reactor-2	NIL TRIPPING						No Outage	
400 kV Motihari - Barh Circuit - 1	5/1/2023 13:50	5/1/2023 16:06	NIL	02:16	NIL	NIL	S/D Taken by RTAMC to remove the Tarpulin stuck at Insulator Strings	
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING						No Outage	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						No Outage	

Darbhanga-Motihari Transmission Company Limited

400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						No Outage
400KV 80MVAR Line Reactor No.1	5/1/2023 13:50	5/1/2023 16:06	NIL	02:16	NIL	NIL	LR S/D with line
400KV 80MVAR Line Reactor No.2	NIL TRIPPING						No Outage
400/132KV 200MVA ICT No.1	5/29/2023 18:29	6/1/2023 0:00	53:31	NIL	NIL	NIL	Tripped due to Differential Protection. Fault Current - B Phase - 1 KA (HV)
400/132KV 200MVA ICT No.2	NIL TRIPPING						No Outage
Motihari 125MVAR Bus Reactor No.1	5/9/2023 19:30	5/15/2023 8:03	NIL	NIL	NIL	132:33	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.1	5/31/2023 20:14	6/1/2023 0:00	NIL	NIL	NIL	03:46	Instructed by ERLDC
Motihari 125MVAR Bus Reactor No.2	5/7/2023 23:38	5/8/2023 8:20	NIL	NIL	NIL	08:42	Instructed by ERLDC

Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL