

# Darbhanga-Motihari Transmission Company Limited

## SCHEDULE I

### AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV -2021

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability		
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)				
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING				No Outage		100%			
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING				No Outage					
400/220KV 500MVA ICT No.1	NIL TRIPPING				No Outage					
400/220KV 500MVA ICT No.2	NIL TRIPPING				No Outage					
Darbhanga 125 MVAr Bus reactor-1	NIL TRIPPING				No Outage					
Darbhanga 125 MVAr Bus reactor-2	NIL TRIPPING				No Outage					
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING				No Outage					
400 kV Motihari - Barh Circuit - 2	11/22/2021 11:31	11/22/2021 11:46	NIL	00:15	NIL	NIL	Line tripped due to DTT received from remote end (Barh NTPC)			
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING				No Outage					
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING				No Outage					
400KV 80MVAR Line Reactor No.1	NIL TRIPPING				No Outage					
400KV 80MVAR Line Reactor No.2	11/22/2021 11:31	11/22/2021 11:45	NIL	00:14	NIL	NIL	Line reactor with line tripped due to DTT received from remote end (Barh NTPC)			
400/132KV 200MVA ICT No.1	NIL TRIPPING				No Outage					
400/132KV 200MVA ICT No.2	NIL TRIPPING				No Outage					
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING				No Outage					
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING				No Outage					

# Darbhanga-Motihari Transmission Company Limited

## SCHEDULE II

### ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

## SCHEDULE III

### DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL