

# Darbhanga-Motihari Transmission Company Limited

## SCHEDULE I

### AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF NOV -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1			NIL TRIPPING					100%
400 KV Darbhanga - Muzaffarpur circuit - 2			NIL TRIPPING					
400/220KV 500MVA ICT No.1			NIL TRIPPING					
400/220KV 500MVA ICT No.2			NIL TRIPPING					
Darbhanga 125 MVAR Bus reactor-1			NIL TRIPPING					
Darbhanga 125 MVAR Bus reactor-2			NIL TRIPPING					
400 kV Motihari - Barh Circuit - 1			NIL TRIPPING					
400 kV Motihari - Barh Circuit - 2			NIL TRIPPING					
400 kV Motihari - Gorakhpur Circuit - 1			NIL TRIPPING					
400 KV Motihari - Gorakhpur Circuit - 2			NIL TRIPPING					
400KV 80MVAR Line Reactor No.1			NIL TRIPPING					
400KV 80MVAR Line Reactor No.2			NIL TRIPPING					
400/132KV 200MVA ICT No.1			NIL TRIPPING					
400/132KV 200MVA ICT No.2			NIL TRIPPING					
Motihari 125MVAR Bus Reactor No.1			NIL TRIPPING					
Motihari 125MVAR Bus Reactor No.2			NIL TRIPPING					

# Darbhanga-Motihari Transmission Company Limited

## SCHEDULE II

### ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

## SCHEDULE III

### DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹ )
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL