

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF OCT -2023

Element name	Outage	Restoration	Duration of Outage Attributable to				Reason Of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmissi on Licensee	Others (Hrs:Min)	System constraint/ Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	NIL TRIPPING							
400/220KV 500MVA ICT No.2	NIL TRIPPING							
Darbhanga 125 MVAR Bus reactor-1	NIL TRIPPING							
Darbhanga 125 MVAR Bus reactor-2	NIL TRIPPING							
400 kV Motihari - Barh Circuit - 1	10/14/2023 8:45	10/14/2023 19:04	NIL	10:19	NIL	NIL	Shutdown taken by RTAMC for insulator cleaning work	
400 kV Motihari - Barh Circuit - 2	10/15/2023 9:08	10/15/2023 17:55	NIL	8:47	NIL	NIL	Shutdown taken by RTAMC for insulator cleaning work	
400 kV Motihari - Barh Circuit - 2	10/27/2023 13:25	10/27/2023 18:10	NIL	4:45	NIL	NIL	Shutdown taken by RTAMC for insulator replacement work	
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING							
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING							
400KV 80MVAR Line Reactor No.1	10/14/2023 8:45	10/14/2023 19:04	NIL	10:19	NIL	NIL	Shutdown taken by RTAMC for insulator cleaning work	
400KV 80MVAR Line Reactor No.2	10/15/2023 9:08	10/15/2023 17:55	NIL	8:47	NIL	NIL	Shutdown taken by RTAMC for insulator cleaning work	

Darbhanga-Motihari Transmission Company Limited

400KV 80MVAR Line Reactor No.2	10/27/2023 13:25	10/27/2023 18:10	NIL	4:45	NIL	NIL	Shutdown taken by RTAMC for insulator replacement work
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						



Darbhanga-Motihari Transmission Company Limited

Corporate Identity Number: U40300MH2012PLC342541

Registered Office: 504 & 505, Windsor, 5th Floor, Off CST Road, Kalina, Santacruz (E),

Mumbai - 400098

E: dmtcl@energy-sel.com T: +91 22 6841 7000 F: +91 22 6841 7077 W: www.sekura.in



Darbhanga-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL