

Darbhanga-Motihari Transmission Company Limited

SCHEDULE I

AC TRANSMISSION LINE/ ICT/ STATIC VAR COMPENSATOR/ SERIES COMPENSATOR/ HVDC (BACK-TO-BACK STATIONS AND BI-POLE LINKS)/ LINE RECTORS/ BUS REACTORS OUTAGE DETAILS FOR THE MONTH OF SEP -2021

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time	Date & Time	Inter-state transmission Licensee (Hrs:Min)	Others (Hrs:Min)	System constraint / Natural calamity/ Militancy (Hrs:Min)	Deemed Available (Hrs:Min)		
400 KV Darbhanga - Muzaffarpur circuit - 1	NIL TRIPPING							100%
400 KV Darbhanga - Muzaffarpur circuit - 2	NIL TRIPPING							
400/220KV 500MVA ICT No.1	9/25/2021 13:18	9/25/2021 13:56	NIL	00:38	NIL	NIL	Tripped in HV directional earth fault protection due to LA blast and fire of remote end 220KV BSPTCL substation	
400/220KV 500MVA ICT No.2	9/25/2021 13:18	9/25/2021 13:59	NIL	00:41	NIL	NIL	Tripped in HV directional earth fault protection due to LA blast and fire of remote end 220KV BSPTCL substation	
Darbhanga 125 MVar Bus reactor-1	9/1/2021 0:00	9/2/2021 6:25	NIL	NIL	NIL	30:25	Voltage regulation	
Darbhanga 125 MVar Bus reactor-2	9/1/2021 20:55	9/3/2021 6:32	NIL	NIL	NIL	33:37	Voltage regulation	
Darbhanga 125 MVar Bus reactor-1	9/4/2021 21:20	9/6/2021 7:40	NIL	NIL	NIL	34:20	Voltage regulation	
Darbhanga 125 MVar Bus reactor-2	9/5/2021 18:57	9/11/2021 4:40	NIL	NIL	NIL	129:43	Voltage regulation	
Darbhanga 125 MVar Bus reactor-1	9/7/2021 20:26	9/11/2021 5:52	NIL	NIL	NIL	81:26	Voltage regulation	
Darbhanga 125 MVar Bus reactor-1	9/11/2021 21:58	9/14/2021 7:21	NIL	NIL	NIL	57:23	Voltage regulation	
Darbhanga 125 MVar Bus reactor-2	9/11/2021 22:00	9/14/2021 9:51	NIL	NIL	NIL	59:51	Voltage regulation	

Darbhangha-Motihari Transmission Company Limited

Darbhangha 125 MVar Bus reactor-1	9/15/2021 20:12	9/16/2021 5:50	NIL	NIL	NIL	09:38	Voltage regulation
Darbhangha 125 MVar Bus reactor-1	9/18/2021 21:07	9/19/2021 6:53	NIL	NIL	NIL	09:46	Voltage regulation
Darbhangha 125 MVar Bus reactor-1	9/19/2021 20:50	9/21/2021 9:23	NIL	NIL	NIL	36:33	Voltage regulation
Darbhangha 125 MVar Bus reactor-1	9/21/2021 19:20	9/25/2021 6:28	NIL	NIL	NIL	83:08	Voltage regulation
Darbhangha 125 MVar Bus reactor-1	9/25/2021 21:07	9/27/2021 16:17	NIL	NIL	NIL	43:10	Voltage regulation
Darbhangha 125 MVar Bus reactor-2	9/26/2021 20:52	9/30/2021 0:00	NIL	NIL	NIL	75:08	Voltage regulation
400 kV Motihari - Barh Circuit - 2	NIL TRIPPING						
400 kV Motihari - Barh Circuit - 1	NIL TRIPPING						
400 kV Motihari - Gorakhpur Circuit - 1	NIL TRIPPING						
400 KV Motihari - Gorakhpur Circuit - 2	NIL TRIPPING						
400KV 80MVAR Line Reactor No.1	NIL TRIPPING						
400KV 80MVAR Line Reactor No.2	NIL TRIPPING						
400/132KV 200MVA ICT No.1	NIL TRIPPING						
400/132KV 200MVA ICT No.2	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.1	NIL TRIPPING						
Motihari 125MVAR Bus Reactor No.2	NIL TRIPPING						

Darbhangha-Motihari Transmission Company Limited

SCHEDULE II

ELEMENTS WHERE RESTORATION TIME HAS EXCEEDED THE STANDARDS SPECIFIED IN REGULATION 5 (B).

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	NIL

SCHEDULE III

DETAILS OF COMPENSATION PAID BY THE INTER-STATE TRANSMISSION LICENSEE

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5(b)		Compensation paid (in ₹)
	% Availability prescribed	Actual % paid (in Rs) Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	NIL	Nil	Nil	NIL